

CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE



January 2007

Submitted to:

City of Manteca
Department of Public Works
1001 West Center Street
Manteca, CA 95337

Prepared by:

Nolte Associates, Inc.
302 Cherry Lane, Suite 201
Manteca, CA 95337
(209) 239-9080 • (209) 239-4166 (Fax)

CONTENTS

	<u>Page</u>
Chapter 1 Introduction	1-1
1.1 Background and Purpose	1-1
1.2 Scope of Master Plan Update	1-1
1.3 Facility Operational History	1-2
1.4 Description of Existing Facilities	1-2
1.5 Phase III Improvements.....	1-5
a. Schedule A Improvements - Northside Nitrification Facilities.....	1-5
b. Schedule B Improvements – Southside Facilities and Influent Pump Station	1-5
c. Schedule C Improvements – Solids Handling Facilities	1-7
d. Schedule D Improvements – Tertiary Filtration and UV Disinfection Facilities.....	1-7
Chapter 2 Regulatory Setting.....	2-1
2.1 Current Discharge Requirements.....	2-1
2.2 Current Effluent Quality	2-2
2.3 Probable Future Effluent Quality	2-3
a. Reduction in Constituents due to Treatment Process Improvements	2-5
b. Improvements in Water Quality Attributable to Source Water Enhancements.....	2-6
c. Constituents Not Impacted by Proposed Facility Configuration.....	2-6
2.4 Probable Future Water Quality Limitations	2-7
a. Biochemical Oxygen Demand (BOD).....	2-8
b. Total Suspended Solids (TSS).....	2-8
c. Total Coliform	2-8
d. Turbidity	2-9
e. Settleable Solids	2-9
f. Chlorine Residual	2-9
g. Oil and Grease	2-9
h. Aluminum.....	2-9
i. Electrical Conductivity	2-9
j. Ammonia	2-10
k. Arsenic.....	2-10
l. Copper	2-10
m. Cyanide.....	2-11
n. Iron.....	2-11
o. Manganese	2-11
p. Methylene Blue Active Substances (MBAS)	2-11
q. Nitrate and Nitrite (as N)	2-11
r. Bis(2-ethylhexyl)phthalate	2-12
s. Bromodichloromethane (BDCM).....	2-12
t. Dibromochloromethane (DBCM).....	2-12
u. Mercury	2-13
v. 2,4,6-Trichlorophenol.....	2-13
w. Other Water Quality Parameters.....	2-13

CONTENTS

	<u>Page</u>
2.5 Comparison of Projected Effluent Quality With Probable Future Quality Limitations.....	2-16
a. Achievable Limits.....	2-17
b. Limits That May Be Achievable	2-18
c. Limits That Are Unlikely to Be Achieved.....	2-18
2.6 Strategy for Future Compliance	2-18
Chapter 3 Projected Flow and Loadings	3-1
3.1 Projected Flow.....	3-1
3.2 Projected Loadings	3-6
a. Future Average WQCF Loadings.....	3-7
b. Peaking Factors.....	3-13
c. Future Peak WQCF Loadings.....	3-13
Chapter 4 Effluent Disposal Strategies	4-1
4.1 On-Site Land Application.....	4-1
4.2 Urban Landscape Irrigation	4-1
4.3 River Discharge	4-2
Chapter 5 Odor Control.....	5-1
5.1 Historical Odor Control Practices.....	5-1
5.2 Potential Odor Services	5-1
5.3 Discussion of Odor Control Techniques	5-1
Chapter 6 Solids Handling Practices.....	6-1
6.1 Description of Solids Handling Facilities.....	6-1
a. Sludge Thickening.....	6-1
b. Sludge Digestion.....	6-2
c. Sludge Dewatering	6-2
6.2 Biosolids Disposal	6-3
Chapter 7 Recommended Facility Improvements.....	7-1
7.1 Influent Pump Station/Mechanical Screening	7-3
7.2 Grit Removal/Primary Sedimentation	7-4
a. Aerated Grit Tanks	7-4
b. Primary Sedimentation Basins.....	7-5
7.3 Aeration Basins with Anoxic Zone	7-6
7.4 Secondary Clarification	7-10
7.5 Return Activated Sludge/Waste Activated Sludge Handling.....	7-11
7.6 Effluent Filtration	7-11
7.7 Rapid Mixing and Flocculation	7-12
7.8 UV Disinfection/Effluent Pumping	7-13
7.9 Chemical Handling, Storage, and Metering	7-14
7.10 Dissolved Air Flotation (WAS Thickening).....	7-15

CONTENTS

	<u>Page</u>
7.11 Anaerobic Digestion and Cogeneration.....	7-15
7.12 Dewatering Facilities.....	7-17
Chapter 8 Probable Construction Costs	8-1
References	R-1

Appendices:

- A Hourly Flow Rates**
- B Urban Water Recycling Opportunities**
- C Route Study for Parallel Land Outfall**
- D Unit Cost Information for Opinion of Probable Construction Costs**
- E Probable Construction Costs for Parallel Land Outfall**

LIST OF TABLES

Table 1-1	City of Manteca Wastewater Quality Control Facility Master Plan Probable Schedule of Phase III Improvements.....	1-5
Table 2-1	City of Manteca Wastewater Quality Control Facility Master Plan Summary of Current Water Quality Requirements for River Discharge	2-1
Table 2-2	City of Manteca Wastewater Quality Control Facility Master Plan Typical Effluent Quality Prior to Phase III Expansion Project	2-2
Table 2-3	City of Manteca Wastewater Quality Control Facility Master Plan Summary of Effluent Quality Sampling for Additional Constituents ^a Prior to Phase III Expansion Project.....	2-3
Table 2-4	City of Manteca Wastewater Quality Control Facility Master Plan Projected Effluent Quality After Phase III Expansion ^a	2-4
Table 2-5	City of Manteca Wastewater Quality Control Facility Master Plan Summary of Probable Future Water Quality Requirements For River Discharge.....	2-7
Table 2-6	City of Manteca Wastewater Quality Control Facility Master Plan Comparison of Probable Future Water Quality Limitations Versus Projected Effluent Quality Following Phase III Expansion Project	2-17
Table 3-1	City of Manteca Wastewater Quality Control Facility Master Plan Wastewater Generation Factors	3-2
Table 3-2	City of Manteca Wastewater Quality Control Facility Master Plan Projected Wastewater Flows – Manteca Only Year 2023 And Buildout Conditions	3-3
Table 3-3	City of Manteca Wastewater Quality Control Facility Master Plan Projected Wastewater Flows	3-4

CONTENTS

		<u>Page</u>
Table 3-4	City of Manteca Wastewater Quality Control Facility Master Plan Summary of Hourly Flow Rates in 2003	3-4
Table 3-5	City of Manteca Wastewater Quality Control Facility Master Plan Summary of Wastewater Flows (mgd).....	3-6
Table 3-6	City of Manteca Wastewater Quality Control Facility Master Plan Summary of Wastewater Loadings Used for Design Purposes.....	3-7
Table 3-7	City of Manteca Wastewater Quality Control Facility Master Plan Comparison of Historical TSS and BOD Influent and Primary Effluent Values	3-11
Table 3-8	City of Manteca Wastewater Quality Control Facility Master Plan Summary of Historical Influent Quality and Anticipated Future Loading at Plant Buildout	3-12
Table 3-9	City of Manteca Wastewater Quality Control Facility Master Plan Summary of Peaking Factors to be Used in the Design of Secondary Treatment Facilities.....	3-13
Table 3-10	City of Manteca Wastewater Quality Control Facility Master Plan Summary of Anticipated Future Loadings at Buildout	3-14
Table 4-1	City of Manteca Wastewater Quality Control Facility Master Plan Recommended Disposal Strategy at Buildout.....	4-2
Table 6-1	City of Manteca Wastewater Quality Control Facility Master Plan Projected Solids Loading at Buildout.....	6-2
Table 7-1	City of Manteca Wastewater Quality Control Facility Master Plan Design Criteria for Plant Expansion Hydraulic Loading.....	7-1
Table 7-2	City of Manteca Wastewater Quality Control Facility Master Plan Design Criteria for Incremental Plant Expansion Summary of Influent Loadings	7-3
Table 7-3	City of Manteca Wastewater Quality Control Facility Master Plan Design Criteria for Incremental Plant Expansion Aerated Grit Tanks	7-5
Table 7-4	City of Manteca Wastewater Quality Control Facility Master Plan Design Criteria for Incremental Plant Expansion Primary Sedimentation Basins	7-6
Table 7-5	City of Manteca Wastewater Quality Control Facility Master Plan Design Criteria for Incremental Plant Expansion Aeration Basin.....	7-8
Table 7-6	City of Manteca Wastewater Quality Control Facility Master Plan Design Criteria for Incremental Plant Expansion Secondary Clarification.....	7-10
Table 7-7	City of Manteca Wastewater Quality Control Facility Master Plan Design Criteria for Incremental Plant Expansion Return Activated Sludge Pumping	7-11
Table 7-8	City of Manteca Wastewater Quality Control Facility Master Plan Tertiary Filtration and UV Disinfection Objectives as Defined in Title 22 Criteria.....	7-12
Table 7-9	City of Manteca Wastewater Quality Control Facility Master Plan Design Criteria for Incremental Plant Expansion Filtration	7-12

CONTENTS

	<u>Page</u>
Table 7-10 City of Manteca Wastewater Quality Control Facility Master Plan Design Criteria for Incremental Plant Expansion rapid mix and flocculation.....	7-13
Table 7-11 City of Manteca Wastewater Quality Control Facility Master Plan Design Criteria for Incremental Plant Expansion UV Disinfection	7-14
Table 7-12 City of Manteca Wastewater Quality Control Facility Master Plan Suggested Chemical Dosages for Filter Aids	7-14
Table 7-13 City of Manteca Wastewater Quality Control Facility Master Plan Design Criteria for Incremental Plant Expansion Dissolved Air Flotation (WAS Thickening)	7-15
Table 7-14 City of Manteca Wastewater Quality Control Facility Master Plan Design Criteria for Incremental Plant Expansion Anaerobic Digestion (Sludge Digestion)	7-16
Table 7-15 City of Manteca Wastewater Quality Control Facility Master Plan Design Criteria for Incremental Plant Expansion Centrifuge (Sludge Dewatering)	7-18
Table 8-1 City of Manteca Wastewater Quality Control Facility Master Plan Probable Construction Costs to Expand Facility from 10 mgd to 27 mgd.....	8-1
Table 8-2 City of Manteca Wastewater Quality Control Facility Master Plan Probable Construction Costs to Expand Facility from 10 mgd to 27 mgd, Cost Breakdown by Phase.....	8-2

LIST OF FIGURES

Figure 1-1	Location of Manteca WQCF	1-3
Figure 1-2	Site Plan of Existing Treatment Plant Prior to Phase III Expansion Project.....	1-4
Figure 1-3	Phase III Expansion Project – Site Plan	1-6
Figure 3-1	WQCF Average Daily Flow in 2003	3-5
Figure 3-2	Daily Average BOD Data from January 2002-January 2004	3-8
Figure 3-3	Daily Average TSS Data from January 2002-January 2004	3-9
Figure 3-4	Daily Average Ammonia Data from January 2002-January 2004	3-10
Figure 7-1	Site Plan at Buildout.....	7-2
Figure 7-2	Site Plan at Phase IV.....	7-19
Figure 7-3	Site Plan at Phase V.....	7-20

LIST OF ABBREVIATIONS

The following abbreviations are used in this report:

ADWF	average dry weather flow
BDCM	Bromodichloromethane
BOD	Biochemical Oxygen Demand
BP	Basin Plan
CIP	capital improvement plan
CS	combined sludge (primary sludge and thickened waste activated sludge)
CTR	California Toxic Rule
DAF	Dissolved air flotation
DHS	California Department of Health Services
DO	dissolved oxygen
DWR	Department of Water Resources
EC	electrical conductivity
HRT	hydraulic retention time
I-5	Interstate 5
IPP	Industrial Pipeline Project
IPS	influent pump station
LAA	Land Application Area
MBAS	Methylene Blue Active Substances
MCL	maximum contaminant level
MCRT	mean cell residence time
MDF	maximum daily flow
mgd	million gallons per day
MHF	maximum hourly flow
MLE	modified Ludzack-Ettinger
MLSS	mixed liquor suspended solids concentration
MUN	Municipal
NSF	Northside facilities
NTU	nephelometric turbidity unit
NPDES	National Pollutant Discharge Elimination System
NWRI	National Water Research Institute
OEHHA	California Office of Environmental Health Hazard Assessment
PFIP	Public Facilities Implementation Plan
PPP	pollution prevention programs
PS	Primary sludge
PSB	primary sedimentation basin

RAS	recycled activated sludge
RWQCB	Regional Water Quality Control Board
SIP	State Implementation Policy
SR-120	State Route 120
SSF	Southside facilities
SSJID	South San Joaquin Irrigation District
TMDL	total maximum daily load
TN	total nitrogen
TSS	Total Suspended Solids
TTHM	Total trihalomethanes
TWAS	thickened waste activated sludge
UMP	updated master plan
VSS	volatile suspended solids
WAS	waste activated sludge
WGF	Wastewater generation factors
WQCF	Manteca Wastewater Quality Control Facility

1 Introduction

In support of a new General Plan and updated Public Facilities Implementation Plan (PFIP), an updated wastewater treatment and disposal master plan is required. Background information, the scope of the master plan update, facility operational history, a description of the treatment facility, and a discussion of the Phase III Expansion Project are presented in this chapter.

1.1 Background and Purpose

The Manteca Wastewater Quality Control Facility (WQCF) is a 6.95 million gallons per day (mgd) rated combined biofilter-activated sludge plant. Secondary effluent is land applied during the spring and summer (flood irrigation for agricultural production) and discharged to the San Joaquin River during the winter (October-March). In the future, year-round discharge to the river is anticipated because of the limited capacity of City-owned land for wastewater applications. In conjunction with the development of the City of Manteca Public Facilities Implementation Plan (PFIP), a master plan for the Manteca WQCF was prepared in 1993 [1]. The master plan included an analysis of existing unit processes, an evaluation of expansion options for the facility, a discussion of disposal alternatives, and a description of phased improvements. The Phase III Expansion Project incorporates the recommendations of the 1993 Master Plan and reflects the current needs and operating requirements for the plant. The capacity of the Manteca WQCF will increase from 6.95 mgd to 9.87 mgd (average dry weather flow) following completion of the Phase III expansion project in 2007. This capacity is anticipated to support City-wastewater requirements for approximately 5-10 years.

Beyond the Phase III expansion, the City has identified the need to program future facilities to accommodate average dry weather flows (ADWF) up to 27 mgd (buildout condition). In addition, the existing land outfall to the San Joaquin River will reach capacity following completion of the Phase III expansion project. Any expansion beyond a capacity of 9.87 mgd will require the construction of a second outfall. In addition, future river discharge requirements are expected to become stricter and may entail additional treatment beyond effluent filtration. In view of these developments, an updated master plan (UMP) that considers stricter water quality requirements, alternative disposal options, and increased flows is warranted.

1.2 Scope of Master Plan Update

The objective of the UMP is to determine what steps will be required to increase the treatment capacity from approximately 10 mgd to 27 mgd while complying with stricter effluent discharge requirements for river discharge. More specifically, the UMP includes the following:

1. A summary of probable future water quality requirements for continued discharge to the San Joaquin River;

2. An assessment of alternative wastewater disposal options with an emphasis on either urban irrigation or expanded agricultural irrigation program;
3. A description of proposed treatment plant improvements for both river and land-based wastewater disposal strategies; and,
4. A detailed capital improvement plan (CIP) that provides appropriate infrastructure to support growth while ensuring compliance with stricter effluent discharge requirements.

1.3 Facility Operational History

The Manteca WQCF is located on 210 acres of City owned property southwest of downtown Manteca at 2450 West Yosemite Avenue (see Figure 1-1). The WQCF treats typical municipal wastewater generated in the City of Manteca and the neighboring City of Lathrop. The plant also receives seasonal discharges from a local food processor (Eckert Cold Storage).

The Manteca WQCF began operation in 1959. At that time the facility consisted solely of an oxidation pond. Pond effluent was discharged to the surrounding land. In 1970, the first major upgrade to the plant occurred. This upgrade included the construction of preliminary and primary treatment facilities and aerobic sludge digestion. Effluent continued to be discharged to the land for agricultural applications. In 1986-1988, as part of the Clean Water Grant Program, a major expansion to the plant was constructed. This Phase I Expansion Project included the construction of secondary treatment facilities, anaerobic sludge digesters, sludge drying beds, a chlorine disinfection system, and an outfall to the San Joaquin River. Design capacity of the plant following the Phase I project was 5.45 mgd (ADWF). The Phase II Expansion Project in 1992-1993 added a primary sedimentation basin, secondary clarifier, and four sludge drying beds, increasing the facility capacity to 6.95 mgd (ADWF).

1.4 Description of Existing Facilities

Currently, the Manteca WQCF consists of an influent pump station with two mechanical screens, two aerated grit tanks, three primary sedimentation basins, a biotower feed pump station, two biotowers, five fine-bubble activated sludge aeration basins, three secondary clarifiers, a secondary effluent storage pond, and two chlorine contact tanks. Solid handling facilities include two dissolved air flotation units, two anaerobic digesters, one centrifugal dewatering system, and drying beds. Undisinfected secondary effluent is used to irrigate approximately 190 acres of City-owned land surrounding the plant. Flows in excess of crop demands are disinfected and discharged to the San Joaquin River.

Anaerobically digested sludge is dewatered, dried, stored on-site, and then transported to a local landfill. A site plan of the existing treatment plant can be seen in Figure 1-2.





FIGURE 1-1
MANTECA WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE
LOCATION OF MANTECA WQCF

NOLTE
 BEYOND ENGINEERING




FIGURE 1-2
MANTECA WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE
 PRIOR TO PHASE III EXPANSION PROJECT
 SITE PLAN OF EXISTING TREATMENT PLANT

NOLTE
 BEYOND ENGINEERING

1.5 Phase III Improvements

The Phase III Expansion Project is divided into four Schedules: A, B, C, and D, respectively (see Figure 1-3). Schedule A was completed in November 2003. Schedule B was substantially complete in November 2005. The anticipated dates for design completion, commencement of construction, and completion of construction for Schedules C and D are summarized in Table 1-1. A brief description of each of the four schedules is provided below.

TABLE 1-1
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
PROBABLE SCHEDULE OF PHASE III IMPROVEMENTS

Project	Complete Design	Begin Construction	Complete Construction
Schedule C, Solids Handling	January 2007	March 2007	June 2008
Schedule D, Effluent Filtration	Completed	January 2006	June 2007

a. Schedule A Improvements - Northside Nitrification Facilities

Schedule A improvements included the construction of two new aeration basins, modifications to three existing secondary clarifier sludge collection mechanisms, and replacement of two existing centrifugal blowers with larger and more energy efficient units within the northside facilities (NSF). Schedule A improvements resulted in an increase in plant capacity from 6.95 to 7.5 mgd (ADWF). Improvements also resulted in the production of a nitrified effluent. Construction of Schedule A began in December 2001 and was recently completed. As part of the Schedule A improvements, the City also procured a skid-mounted centrifugal dewatering system to dewater anaerobically digested primary and secondary sludges to augment the existing drying bed facilities.

b. Schedule B Improvements – Southside Facilities and Influent Pump Station

Schedule B improvements included the construction of a new influent pump station, two aerated grit tanks, three primary sedimentation basins, five aeration basins, two secondary clarifiers, and an odor control biofilter. These primary and secondary treatment facilities are referred to as the southside facilities (SSF). Schedule B improvements also included the expansion of the existing laboratory and administration building. Schedule B improvements increased the treatment capacity of the plant from 7.5 mgd to 9.87 mgd (ADWF). Effluent, at the completion of Schedule B, will be nitrified and denitrified.




FIGURE 1-3
MANTECA WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE
PHASE III EXPANSION PROJECT - SITE PLAN
NOLTE
BEYOND ENGINEERING

c. Schedule C Improvements – Solids Handling Facilities

The improvements proposed under Schedule C primarily involve solids handling. Under Schedule C, a mechanical dewatering facility will be constructed. The skid-mounted centrifugal dewatering system acquired under Schedule A will be relocated to a new dewatering building. Additional improvements to occur under Schedule C include the construction of a shop maintenance building and development of a paved biosolids stockpile area.

d. Schedule D Improvements – Tertiary Filtration and UV Disinfection Facilities

Proposed Schedule D improvements include the construction of a secondary effluent equalization pond, filter feed pump station, coagulation and flocculation facilities, tertiary filters, a chemical storage and handling facility, a UV disinfection system, an effluent pumping station, and two odor control biofilters. In addition to flow attenuation, the secondary effluent equalization pond will store water during periods of reverse river flow due to tidal influence in the San Joaquin River.

1.6 Industrial Pipeline Phase 3

Although not part of the Phase III Expansion Project, the City has initiated additional efforts to improve plant operations and effluent quality. Under the Industrial Pipeline Project Phase 3 (IPP-3), the existing secondary effluent storage pond will be modified to create a second lined pond for food processing wastewater from Eckert Cold Storage (Eckert). In the past, high-strength Eckert wastewater has been co-mingled with domestic wastewater and processed through the WQCF prior to disposal. IPP-3 is the final component in a source separation program designed to allow independent treatment of Eckert wastewater prior to land application at the WQCF. By segregating industrial wastewater, the operation of the plant facilities can be optimized with less risk of potential process upsets.

c. Schedule C Improvements – Solids Handling Facilities

The improvements proposed under Schedule C primarily involve solids handling. Under Schedule C, a mechanical dewatering facility will be constructed. The skid-mounted centrifugal dewatering system acquired under Schedule A will be relocated to a new dewatering building. Additional improvements to occur under Schedule C include the construction of a shop maintenance building and development of a paved biosolids stockpile area.

d. Schedule D Improvements – Tertiary Filtration and UV Disinfection Facilities

Proposed Schedule D improvements include the construction of a secondary effluent equalization pond, filter feed pump station, coagulation and flocculation facilities, tertiary filters, a chemical storage and handling facility, a UV disinfection system, an effluent pumping station, and two odor control biofilters. In addition to flow attenuation, the secondary effluent equalization pond will store water during periods of reverse river flow due to tidal influence in the San Joaquin River.

1.6 Industrial Pipeline Phase 3

Although not part of the Phase III Expansion Project, the City has initiated additional efforts to improve plant operations and effluent quality. Under the Industrial Pipeline Project Phase 3 (IPP-3), the existing secondary effluent storage pond will be modified to create a second lined pond for food processing wastewater from Eckert Cold Storage (Eckert). In the past, high-strength Eckert wastewater has been co-mingled with domestic wastewater and processed through the WQCF prior to disposal. IPP-3 is the final component in a source separation program designed to allow independent treatment of Eckert wastewater prior to land application at the WQCF. By segregating industrial wastewater, the operation of the plant facilities can be optimized with less risk of potential process upsets.

2 Regulatory Setting

Future facility requirements are dictated by water quality regulations. A discussion of the regulatory setting for the Manteca WQCF is presented in this chapter.

2.1 Current Discharge Requirements

The Manteca WQCF operates under Regional Board Order No. R5-2004-0028 (NPDES Permit No. CA0081558) issued by the State of California Regional Quality Control Board (RWQCB) [2]. Water quality parameters for river discharge are summarized in Table 2-1. As seen in Table 2-1, beyond February 2009, water quality limitations will become more stringent for BOD, TSS, total coliform, and turbidity.

TABLE 2-1
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
SUMMARY OF CURRENT WATER QUALITY REQUIREMENTS
FOR RIVER DISCHARGE

Constituent	Units	Requirement ^a (Effective through January 31, 2009)	Requirement (Effective as of February 1, 2009)
BOD	mg/L	20	10
TSS	mg/L	20	10
Total Coliform	MPN/100 mL	23 ^b	2.2 ^b
Turbidity	NTU	--	2 ^c
Settleable Solids	mg/L	0.1	0.1
Chlorine Residual	mg/L	0.01 ^{db}	0.01 ^d
Oil and Grease	mg/l	10	10
Aluminum	µg/L	71	71
Conductivity	µmhos/cm	1,000	1,000
Ammonia (as N)			
June through September	mg/L	2.1	2.1
October through May	mg/L	2.8	2.8
Arsenic	µg/L	10	10
Copper	µg/L	7.9	7.9
Cyanide	µg/L	3.7	3.7
Iron	µg/L	300	300
Manganese	µg/L	50	50
Methylene Blue Active Substances (MBAS)	µg/L	500	500
Nitrate (as N)	mg/L	10	10
Nitrite (as N)	mg/L	1	1

*City of Manteca
Wastewater Quality Control Facility Master Plan
Chapter 2: Regulatory Setting*

Constituent	Units	Requirement ^a (Effective through January 31, 2009)	Requirement (Effective as of February 1, 2009)
Bis (2-ethylhexyl) phthalate	µg/L	22	22
Bromodichloromethane	µg/L	5	5
Dibromochloromethane	µg/L	1.4	1.4
Mercury	lb/yr	0.69 ^e	0.69 ^e
2,4,6-Trichlorophenol	µg/L	34	34

^a Monthly average, unless noted otherwise

^b Weekly median

^c 24-hour average

^d 4 day average

^e Corresponds to 0.028 µg/L for the average treatment design capacity of 8.11 mgd

2.2 Current Effluent Quality

Typical effluent quality (for conventional parameters) prior to the Phase III Expansion Project is presented in Table 2-2. The results of effluent sampling during 2002 for additional constituents are summarized in Table 2-3.

**TABLE 2-2
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
TYPICAL EFFLUENT QUALITY PRIOR TO PHASE III EXPANSION PROJECT**

Constituent	Units	Effluent Quality 30-day Average
BOD ₅	mg/L	16
Settleable Solids	mg/L	0.1
Total Suspended Solids	mg/L	19
Total Coliform Organisms	MPN/100 mL	23 ^a
Oil and Grease	mg/L	2.1
Chlorine Residual	mg/L	--
Ammonia	mg/L	20

^a Weekly median value

**TABLE 2-3
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
SUMMARY OF EFFLUENT QUALITY SAMPLING
FOR ADDITIONAL CONSTITUENTS^a
PRIOR TO PHASE III EXPANSION PROJECT**

Constituent	Units	Range	Mean	Maximum
Aluminum	µg/L	70 - 350	150	350
Conductivity	µmhos/cm	819 - 1300	1099	1300
Arsenic	µg/L	11 - 14	12.5	14
Copper	µg/L	6.8 - 13	9	13
Cyanide	µg/L	6 - 31	7	31
MBAS ^b	µg/L	120 - 1800	620	1800
Nitrate (as N)	mg/L	1 - 7.1	-	-
Nitrite (as N)	mg/L	0.12 - 1.80	-	-
Bis (2-ethylhexyl) phthalate	µg/L	0.9 - 7	3.48	7
Bromodichloromethane	µg/L	1 - 3.5	1.98	3.5
Dibromochloromethane	µg/L	ND ^c - 1.2	0.47	1.2
Mercury	µg/L	0.013 - 0.028	-	-
2,4,6-Trichlorophenol	µg/L	0 - 11	3.28	11

^a Based on 2002 monitoring results for all constituents except conductivity, MBAS, nitrate, and nitrite. Monitoring results for MBAS, conductivity, nitrate, and nitrite extend from 1998-2002.

^b Methylene Blue Active Substances.

^c Non-detect.

2.3 Probable Future Effluent Quality

An analysis of probable effluent quality following the completion of proposed improvements scheduled as part of the Phase III Expansion Project is presented below.

Current plant effluent quality is expected to improve significantly after the completion of Phase III modifications and expansion. The removal of ammonia and total nitrogen are the major effluent quality enhancements anticipated under Schedule A and Schedule B of the Phase III Project, respectively. Phase III Schedule D improvements will further improve the effluent quality to meet Title 22 wastewater reuse criteria for total suspended solids, turbidity, BOD, and total coliforms. Effluent quality values for conventional parameters, which served as design objectives for the Phase III Expansion project, are presented in Table 2-4. To determine removal efficiencies for certain constituents following completion of the proposed modifications and expansions, reported removal efficiencies at similar facilities in Northern California were investigated to bracket probable process performance.

TABLE 2-4
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
PROJECTED EFFLUENT QUALITY AFTER PHASE III EXPANSION^a

Constituents	Units	Schedule A	Schedule B	Schedule D
BOD	mg/L	15	10	7
Total Suspended Solids	mg/L	15	10	< 10
Total Coliform	MPN/100 mL	23	23	< 2.2
Turbidity	NTU	8	8	< 2
Settleable Solids	mg/L	0.1	0.1	0.1
Chlorine Residual	mg/L	0.01	0.01	0.01
Oil and Grease	mg/L	2.1	2.1	2.1
Aluminum	µg/L	150	150	150
Electrical Conductivity	µmhos/cm	1100	1100	825
Ammonia	mg/L	2.1	1.5	1.5
Arsenic	µg/L	12.5	12.5	8
Copper	µg/L	9	9	7
Cyanide	µg/L	7	7	1
Iron ^b	µg/L	47	47	47
Manganese ^b	µg/L	15	15	15
MBAS	µg/L	160	160	160
Nitrate (as N)	mg/L	10	5	5
Nitrite (as N)	mg/L	1	1	1
Bis (2-ethylhexyl) phthalate	µg/L	3.48	3.48	3.48
Bromodichloromethane	µg/L	1.98	1.98	ND ^c
Dibromochloromethane	µg/L	0.47	0.47	ND ^c
Mercury	µg/L	0.028	0.028	0.010
2,4,6-Trichlorophenol	µg/L	3.28	3.28	3.28

^a Projected mean values.

^b Concentration represents median value taken from analysis at WQCF effluent evaluated as part of WQCF Special Studies Monitoring Program

^c Non-detect.

The projected effluent quality following each stage of construction is presented in Table 2-4. Projected effluent concentrations reflect baseline values established for secondary treatment at the WQCF and anticipated facility enhancements. These concentrations were developed considering the following:

1. Historical WQCF secondary effluent values prior to Phase III Schedule A improvements. For planning purposes, average (mean) and maximum measured values were used to determine effluent quality.
2. Anticipated improvements in potable water quality due to groundwater treatment and introduction of a surface water supply source.

3. Typical removal efficiencies reported in the literature for similar treatment facilities including a survey of six San Francisco Bay area treatment plants (Petaluma, Palo Alto, Half Moon Bay, Napa, Calistoga, San Jose-Santa Clara).
4. Results of special studies undertaken at WQCF effluent.

A discussion of specific effluent quality parameters follows below. The discussion is organized into three areas: a) Reduction in constituents due to treatment process improvements; b) improvements in water quality attributable to source water enhancements; and c) constituents not impacted by the proposed facility configuration following the Phase III Expansion.

a. Reduction in Constituents due to Treatment Process Improvements

The upgrade of the activated sludge process and the addition of tertiary filtration will significantly impact conventional pollutant concentrations. These are discussed as follows.

BOD, Suspended Solids, Coliform, Organics: With a high-rate activated sludge process, an easily filterable secondary effluent will be produced. Following tertiary filtration in accordance with Title 22 standards and UV disinfection conforming to National Water Research Institute (NWRI) guidelines, BOD and suspended solids concentrations will be less than 10 mg/L consistently (approximately 7 mg/L), turbidities will be less than 2 NTU, while total coliform levels will be less than 2.2 MPN/100 mL. In terms of organics and mercury, based on historical operating experience at other facilities, unless chlorination is practiced, effluent concentrations of bromodichloromethane and dibromochloromethane should be at the non-detect level while mercury levels should be less than 0.010 µg/L.

Nitrogen: A high level of nitrogen removal will be accomplished through the activated sludge nitrification – denitrification process. Ammonia will be largely converted to nitrate and nitrite. Denitrification facilities will then essentially complete the nitrogen removal process through the conversion of nitrates and nitrites to nitrogen gas.

Copper: The mean and maximum effluent values observed for copper prior to the Phase III Expansion were 9 µg/L and 13 µg/L respectively. Historical removal efficiencies at similar advanced treatment plants are on the order of 25 percent. Considering 25 percent removal through advanced wastewater treatment (filtration), mean and maximum effluent concentrations of 7 µg/L and 10 µg/L are anticipated for copper.

Cyanide: The mean and maximum effluent values observed for cyanide prior to the Phase III expansion were 7 µg/L and 31 µg/L. Removal of cyanide with filtration is insignificant. Some coincidental removal may occur but is likely in the 5 - 10 percent range. Cyanide concentrations will likely be reduced, however, with UV disinfection. Cyanide has not been detected at any of the city wells, and there are no known industrial dischargers. Because source water changes will not impact cyanide levels and removal efficiencies through UV disinfection are significant, a maximum effluent concentration of 1 µg/L is predicted.

Methylene Blue Active Substances (MBAS): The mean and maximum effluent values observed for MBAS prior to the Phase III expansion were 620 µg/L and 1,800 µg/L. MBAS is removed through the biological treatment processes. The upgrade of the activated sludge process to full nitrification (Schedule A) will increase the removal efficiency for MBAS. Based on 75 percent removal, the MBAS concentration is expected to decrease to approximately 450 µg/L (maximum). The anticipated future mean concentration is 160 µg/L following completion of Phase III improvements.

b. Improvements in Water Quality Attributable to Source Water Enhancements

The City of Manteca is implementing two major programs to enhance source water quality: arsenic treatment of groundwater and participation in a surface water supply project. Specific reductions in effluent concentrations due to source water changes are described below.

Arsenic: The maximum effluent value observed for arsenic prior to the Phase III expansion was 14 µg/L. Arsenic in the WQCF effluent originates from groundwater with concentrations ranging from 5 - 20 µg/L. Arsenic is not generated during the treatment process at the WQCF. Treatment will be implemented, however, at City wells to reduce arsenic concentrations to 8 µg/L. Based on the source water improvements, an average effluent concentration of 8 µg/L at the WQCF may be achievable if the water treatment target is achieved and no other arsenic is added as a compound of wastewater.

Electrical Conductivity: The WQCF effluent value for electrical conductivity ranged from 819 - 1300 µmhos/cm during 2003. Electrical conductivity is largely a function of source water quality and mineral pick-up during water use. The relatively high value of electroconductivity (and corresponding salinity) is due to the exclusive use of groundwater in the City. Because chemical addition at the WQCF is seldom practiced, additional increases in electroconductivity at the plant are unlikely.

In the future, surface water from the South County Water Supply Program will be introduced and blended with groundwater for the City water supply. The conductivity of surface water is approximately 100 µmhos/cm. Considering the likely blend of surface water and groundwater for the potable water supply, electrical conductivity is expected to decrease up to 25 percent leading to a similar decrease in plant effluent conductivity. These conductivity levels in the effluent are not certain until the actual water supply conditions have stabilized.

c. Constituents Not Impacted by Proposed Facility Configuration

A number of dissolved constituents will largely pass through the treatment plant and not be removed appreciably as part of the facility improvements/reconfiguration. These include aluminum, iron, bis (2-ethylhexyl) phthalate and 2,4,6-trichlorophenol. Because reductions in concentrations are unlikely, predicted future values represent the median of historical measured values.

2.4 Probable Future Water Quality Limitations

A summary of probable future water quality requirements beyond Year 2009 for continued discharge to the San Joaquin River is presented below. Probable future water quality requirements are based on information in the current NPDES permit. The RWQCB considers the new permit to include the most stringent water quality criteria foreseeable for the WQCF discharge.

A discussion of each of the water quality parameters is presented along with the future probable permit level considering the current NPDES permit, relevant water quality criteria, and the results of site specific studies. Probable future water quality requirements along with the relevant water quality criteria are summarized in Table 2-5.

TABLE 2-5
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
SUMMARY OF PROBABLE FUTURE WATER QUALITY REQUIREMENTS
FOR RIVER DISCHARGE

Constituent ^a	Units	Probable Future Requirement (monthly average unless noted otherwise)	Relevant Most Stringent Water Quality Criteria
BOD	mg/L	10 or lower	--
TSS	mg/L	10 or lower	--
Total Coliform	MPN/100 mL	2.2 ^b	2.2
Turbidity	NTU	2 ^c	2
Settleable Solids	mg/L	0.1	--
Chlorine Residual	mg/L	0.01 ^d	0.011
Oil and Grease	mg/L	10	--
Aluminum	µg/L	71	87
Conductivity	µmhos/cm	1,000	1,000
Ammonia (as N)			
June through September	mg/L	2.1 or lower	0.62
October through May	mg/L	2.8	5.62
Arsenic	µg/L	10	10
Copper	µg/L	7.9	10
Cyanide	µg/L	3.7	10
Iron	µg/L	300	300
Manganese	µg/L	50	50
MBAS	µg/L	500	500
Nitrate (as N)	mg/L	10	10

Constituent ^a	Units	Probable Future Requirement (monthly average unless noted otherwise)	Relevant Most Stringent Water Quality Criteria
Nitrite (as N)	mg/L	1	1
Bis (2-ethylhexyl) phthalate	µg/L	22	1.8
Bromodichloromethane	µg/L	5	0.56
Dibromochloromethane	µg/L	1.4	0.41
Mercury	--	0.69 lb/yr or lower ^e	0.05 µg/L
2,4,6-Trichlorophenol	µg/L	34	2.1

^a For constituents listed under the current NPDES permit

^b Weekly median

^c 24 hour average using 1 hour average values

^d 4-day average

^e Corresponds to 0.023 µg/L for the average design treatment capacity of 9.87 mgd

a. Biochemical Oxygen Demand (BOD)

The Basin Plan (BP) prescribes a minimum dissolved oxygen (DO) concentration in the San Joaquin River of 5 mg/L [3]. This standard is applicable throughout the year. The Bay/Delta plan prescribes a minimum DO concentration of 6.0 mg/L in the San Joaquin River within the reach from Turner Cut to Stockton from September through November. The DO objectives are not met frequently in the San Joaquin River, leading to the Clean Water Act section 303(d) listing. A total maximum daily load (TMDL) implementation plan was submitted to the RWQCB in February 2003. The TMDL was developed and submitted to the EPA in June 2003. Further action by the City to reduce its impact on the San Joaquin River DO concentration, beyond the BOD requirements of the new permit will not be required by the RWQCB until the TMDL for DO has been approved by EPA. The new NPDES order contains a provision to allow for modifications to the BOD effluent limitation after the DO TMDL is finalized. As such, future BOD effluent requirement may be reduced below 10 mg/L based on the results of the DO TMDL study.

b. Total Suspended Solids (TSS)

The DO TMDL discussed above will also be used to evaluate the future requirements for TSS. The new NPDES order contains a provision to allow for modifications for the TSS effluent limitation after the DO TMDL is finalized. Similarly, future TSS effluent requirement may be reduced below 10 mg/L based on the results of the DO TMDL study.

c. Total Coliform

The total coliform requirements in the new NPDES permit are expected to remain unchanged in the future.

d. Turbidity

The new NPDES permit requires the daily average effluent turbidity to be less than 2 NTU. An effluent turbidity of 2 NTU is equivalent to approximately 3-5 mg/L TSS, which is half of the permitted TSS requirement. Considering TSS requirements, the turbidity values in the new NPDES permit are assumed to remain unchanged in the future.

e. Settleable Solids

The settleable solids requirements in the new NPDES permit are expected to remain unchanged in the future.

f. Chlorine Residual

The BP contains a narrative toxicity objective. EPA ambient water quality criteria for chlorine (for protection of fresh aquatic life) were used in the new NPDES permit to implement the narrative toxicity objective. Chlorine requirements specified in the new NPDES permit are expected to remain unchanged in future permits assuming EPA water ambient water quality criteria for chlorine is not modified in the future.

g. Oil and Grease

The oil and grease requirements in the new NPDES permit are expected to remain unchanged in the future.

h. Aluminum

The BP contains a narrative toxicity objective, and chemical constituents water quality objective prohibits chemical constituents in concentrations that exceed state maximum contaminant levels (MCLs) or that adversely affect beneficial uses. MUN is a beneficial use of the San Joaquin river. To implement the narrative toxicity objective, the EPA ambient water quality criteria for aluminum (for protection of fresh aquatic life) was used to establish the requirement for aluminum in the new NPDES permit. No dilution credit was given in the development of the aluminum limitation, therefore limits specified in the new NPDES permit are not expected to change significantly in the future assuming EPA water ambient water quality criteria for aluminum is not modified.

i. Electrical Conductivity

The BP chemical constituent water quality objective incorporates state MCLs, and contains numeric water quality objectives for electrical conductivity (EC). Based on the results of the TMDL study for salinity and boron in lower San Joaquin river, the RWQCB concluded that the

receiving water frequently has no assimilative capacity for EC. The EC effluent limitations in the new NPDES permit are based on the BP water quality objective in the South Delta.

Future NPDES EC limitations are not expected to change significantly assuming BP chemical water quality objectives are not modified.

j. Ammonia

Ammonia effluent limitations included in the new NPDES permit are based on the BP narrative toxicity objective and the EPA ambient water quality criteria (for the protection of freshwater aquatic life) for ammonia. Ammonia limitations in the new NPDES permit from October through May are based on acute levels which are more stringent than chronic levels during cold weather conditions. Ammonia limitations from June through September are based on chronic levels which are more stringent than acute levels during warm weather.

No dilution credit was given in the NPDES effluent ammonia limitation calculations during cold weather period, therefore future limitations from October through May are not expected to change significantly assuming BP objectives and the EPA ambient water quality criteria for ammonia is not modified. A dilution credit of four to one was used in effluent ammonia limitation calculations during the warm weather period in the permit, therefore a more stringent ammonia limit for the period from June through May may be adopted if a lower dilution factor is applied in the future.

k. Arsenic

The arsenic effluent limitation included in the new NPDES permit is based on the BP numeric objective for San Joaquin-Sacramento Delta. The BP objective and EPA primary MCL are more stringent than the California Toxic Rule (CTR) criteria for arsenic. Arsenic limitations in the NPDES are calculated based on acute levels which are also more stringent than chronic levels. No dilution credit was given in the new NPDES effluent limitation calculation for arsenic, therefore future limitations are not expected to change significantly assuming the BP objective and arsenic primary MCL are not modified.

l. Copper

The copper effluent limitation included in the new NPDES permit is based on the BP objectives for the protection of fresh water species. The BP objective is more stringent than the CTR criteria for copper. Copper limitations in the NPDES are calculated based on acute levels which are more stringent than chronic levels. No dilution credit was given and the default EPA translator was used in the NPDES effluent limitation calculation for copper, therefore future limitations are not expected to change significantly assuming the BP objective is not modified.

m. Cyanide

The cyanide effluent limitation included in the new NPDES permit is based on the BP objective. The BP objective is more stringent than the CTR criteria for cyanide. The cyanide limitation is calculated based on acute levels which are more stringent than chronic levels. No dilution credit was given in the NPDES effluent limitation calculation for cyanide; therefore, the future cyanide limitation is not expected to change significantly assuming the BP objective is not modified.

n. Iron

The BP chemical constituent objective includes a receiving water objective for iron in the Delta and a secondary MCL for iron in drinking water. The iron effluent limitation included in the new NPDES permit is based on the BP chemical constituents objective for iron. No dilution credit was given in the NPDES effluent limitation calculation for iron, therefore the future iron limitation is not expected to change significantly assuming the BP chemical constituents objective is not modified.

o. Manganese

The BP chemical constituent objective includes a receiving water objective for manganese in the Delta, and a secondary MCL for manganese in drinking water. The manganese effluent limitation included in the NPDES permit is based on the BP chemical constituents objective for manganese. No dilution credit was given in the NPDES effluent limitation calculation for manganese, therefore the future manganese limitation is not expected to change significantly assuming the BP chemical constituents objective is not modified.

p. Methylene Blue Active Substances (MBAS)

The BP includes the chemical constituents objective that incorporates state MCLs for waters designated as MUN (Municipal). MBAS concentrations in excess of the secondary MCL-consumer acceptance limit produce aesthetically undesirable froth, taste, and odor. The MBAS effluent limitation included in the NPDES permit is based on the BP water quality objectives for chemical constituents, floating material, and taste/odors. No dilution credit was given in the NPDES effluent limitation calculation for MBAS, therefore the future limitation is not expected to change significantly assuming the BP chemical water quality objectives are not modified.

q. Nitrate and Nitrite (as N)

The BP chemical constituents water quality objective prohibits chemical constituents in concentrations that exceed drinking water MCLs published in Title 22 of the California Code of regulations or that adversely affect beneficial uses. Municipal and domestic water supplies are beneficial uses of the San Joaquin river. The California Department of Health Services (DHS) has adopted primary MCLs for the protection of human health for nitrite and nitrate. NPDES effluent limitations for nitrite and nitrate are based on the primary MCLs. Future nitrite and

nitrate limitations are not expected to change significantly assuming primary MCLs for nitrite and nitrate are not modified.

r. Bis(2-ethylhexyl)phthalate

The CTR includes standards for the protection of human health based on a one in a million cancer risk for carcinogenic constituents like Bis(2-ethylhexyl)phthalate. The effluent limitation in the NPDES for Bis(2-ethylhexyl)phthalate is based on the Bis(2-ethylhexyl)phthalate CTR criteria for the protection of human health. The human health based criteria are based on lifetime exposures. The effluent limitation calculation procedures in the State Implementation Policy (SIP) allow for granting a dilution credit. However, the RWQCB is not required to grant a mixing zone or allocate the full assimilative capacity of the receiving water. Bis(2-ethylhexyl)phthalate was not detected in the receiving water. A steady state analysis utilizing the harmonic mean flow of San Joaquin River at Vernalis and the permitted discharge flow (based on Phase III expansion) provides a dilution ratio of 162:1. For limitations based on human health criteria, the dilution credit is limited to the amount required to maintain compliance. The dilution credit required to maintain compliance for Bis(2-ethylhexyl)phthalate was established as 13.3 in the new NPDES permit.

The dilution ratio of 162:1 (based on the Phase III Expansion flow) is estimated to decrease to approximately 60:1 at an increased WQCF discharge of 27 mgd in the future. Because the required dilution credit of 13.3 is significantly lower compared to the estimated future dilution ratio of 60:1, future limitation for Bis(2-ethylhexyl)phthalate is not expected to change significantly assuming the CTR criteria for Bis(2-ethylhexyl)phthalate is not modified.

s. Bromodichloromethane (BDCM)

The CTR includes standards for the protection of human health based on a one in a million cancer risk for carcinogenic constituents like BDCM. The effluent limitation in the NPDES for BDCM is based on the BDCM CTR criteria for the protection of human health. BDCM was not detected in the receiving water. The dilution credit required to maintain compliance for BDCM was established as 11.5 in the new NPDES permit.

As discussed previously, the dilution ratio is projected to decrease to approximately 60:1 in the future. Because the dilution credit of 11.5 is significantly lower than the estimated future dilution ratio of 60:1, the future BDCM limitation is not expected to change significantly assuming the CTR criteria for BDCM is not modified.

t. Dibromochloromethane (DBCM)

The CTR includes standards for the protection of human health based on a one in a million cancer risk for carcinogenic constituents like DBCM. The effluent DBCM limitation in the new NPDES is based on the DBCM CTR criteria for the protection of human health. Dibromochloromethane was not detected in the receiving water. The dilution credit required to

maintain compliance for DBCM was established as 8.9 in the new NPDES permit. As noted earlier, the dilution ratio is projected to decrease to approximately 60:1 in the future. Because the required dilution credit of 8.9 is significantly lower than the estimated future dilution ratio of 60:1, the future DBCM limitation is not expected to change significantly assuming the DBCM CTR criteria is not modified.

u. Mercury

The mercury limitation in the new NPDES permit was established based on the BP narrative toxicity objective and the issues related to bioaccumulation of mercury in fish tissue. There is currently no assimilative capacity for mercury in the San Joaquin River. A TMDL for mercury is under development. The interim mercury limitation in the NPDES permit for mercury is based on the maximum mercury concentration observed in the WQCF effluent and resultant annual mass loading from the maximum concentration. A lower mercury limitations may be adopted upon the development of the TMDL, if the RWQCB determines that a mercury offset program is feasible for dischargers subject to a NPDES permit.

Even though the WQCF effluent does not contain significant levels of mercury (the maximum observed WQCF effluent mercury concentration of 0.028 µg/L is less than the water and organism criteria of 0.05 µg/L), future NPDES permits may have more stringent mercury limitations because of the following: 1) there is currently no assimilative capacity for mercury in the San Joaquin River; 2) the receiving water has much lower mercury levels (0.0036-0.0093 µg/L in receiving water versus 0.013-0.028 µg/L in WQCF effluent); and, 3) the TMDL study may impose lowered mercury load allocations for the WQCF.

v. 2,4,6-Trichlorophenol

The CTR includes standards for the protection of human health based on a one in a million cancer risk for carcinogenic constituents like 2,4,6-Trichlorophenol. The effluent limitation in the NPDES permit for 2,4,6-Trichlorophenol is based on the 2,4,6-Trichlorophenol CTR criteria for the protection of human health. 2,4,6-Trichlorophenol was not detected in the receiving water. The dilution credit required to maintain compliance for 2,4,6-Trichlorophenol was established as 16.9 in the new NPDES permit.

As discussed previously, the dilution ratio is estimated to decrease to approximately 60:1 in the future. Because the required dilution credit of 16.9 is significantly lower than the estimated future dilution ratio of 60:1, future 2,4,6-Trichlorophenol limitation is not expected to change significantly assuming the CTR criteria for 2,4,6-Trichlorophenol is not modified.

w. Other Water Quality Parameters

Although limits were not imposed in the new NPDES permit, a number of additional water quality parameters were addressed. Because these parameters may be included in future permits, each is discussed below.

Molybdenum: Molybdenum was not monitored in the plant effluent or in the receiving water. A molybdenum limitation may be included in the new and/or future permits, if future monitoring shows a reasonable potential to deteriorate a water quality objective. The likely limitation would be 10 µg/L (without any dilution credit), which is the recommended agricultural water quality goal for molybdenum to implement the BP narrative chemical constituent objective.

Carbofuran: Carbofuran was detected in the effluent and receiving water, but exact levels were not quantified due to the laboratory's reporting limit for carbofuran. If future monitoring shows a reasonable potential to deteriorate a water quality objective, a carbofuran limitation may be included in the new and/or future permits. The likely limitation will be 18 µg/L (without any dilution credit), which is the MCL criteria for carbofuran. The State of California Office of Environmental Health Hazard Assessment (OEHHA) criterion for carbofuran, which is 1.7 µg/L, may also be adopted instead of the carbofuran MCL.

Zinc: The discharge currently does not have a reasonable potential to cause or contribute to an in-stream excursion above the water quality objective by exceeding the CTR MCL for zinc. Zinc may be included in future NPDES permits because the maximum observed concentration of 42 µg/L is close to the current criteria (continuous maximum criteria is 48 µg/L and the BP objective is 100 µg/L).

Lindane: The discharge currently does not have a reasonable potential to cause or contribute to an in-stream excursion above the water quality criteria for lindane. Lindane was not detected in the WQCF effluent (at a reporting limit of 0.01 µg/L). Lindane should not be present in detectable concentrations according to the BP. The acceptable detection limit for Lindane is 0.02 µg/L. Lindane may be included in future NPDES permits if concentrations above accepted detection limits are observed in the future.

Endrin Aldehyde: The discharge currently does not have a reasonable potential to cause or contribute to an in-stream excursion above the water quality criteria for Endrin aldehyde. Endrin aldehyde was not detected in the WQCF effluent (at a detection level of 0.01 µg/L). Endrin aldehyde should not be present in detectable concentrations according to the BP. The acceptable detection limit for Endrin aldehyde is 0.01 µg/L. Endrin aldehyde may be included in future NPDES permits if concentrations above accepted detection limits are observed in the future.

4,4'-DDT: The discharge currently does not have a reasonable potential to cause or contribute to an in-stream excursion above the water quality criteria for 4,4'-DDT. 4,4'-DDT was not detected in the WQCF effluent (at a reporting level of 0.01 µg/L). 4,4'-DDT should not be present in detectable concentrations according to the BP. The acceptable detection limit for 4,4'-DDT is 0.01 µg/L. 4,4'-DDT may be included in future NPDES permits if concentrations above accepted detection limits are observed in the future.

PCBs: The discharge currently does not have a reasonable potential to cause or contribute to an in-stream excursion above the water quality criteria for PCBs. PCBs were not detected in the

WQCF effluent at a reporting level of 0.1 µg/L. However, the reporting limit for PCBs was not low enough to compare with the relevant CTR criteria of 0.00017 µg/L. PCBs will be monitored at lower detection limits and may be included in future NPDES permits if concentrations above the CTR criteria are observed .

2,3,7,8-TCDD (Dioxin): The discharge currently does not have a reasonable potential to cause or contribute to an in-stream excursion above the water quality criteria for dioxin. Dioxin was not detected in the WQCF effluent at a reporting level of 0.975 pg/L. However, the reporting limit for dioxin is not low enough to compare with the relevant CTR criteria of 0.013 pg/L. Dioxin will be monitored at lower detection limits and may be included in future NPDES permits if concentrations above the CTR criteria are observed .

Total Trihalomethanes and Chloroform: The discharge does not have a reasonable potential to cause or contribute to an in-stream excursion above the water quality objective for MUN use by exceeding the EPA primary MCL for TTHMs or the OEHHA criteria for chloroform. TTHMs and chloroform will decrease in the future (reducing the reasonable potential levels) when the chlorination system is replaced by UV disinfection.

Chloromethane: The discharge does not have a reasonable potential to cause or contribute to an in-stream excursion above the water quality criteria. One possible source of chloromethane is chlorination. Lower levels of chloromethane may be observed in the future (reducing the reasonable potential levels) when the chlorination system is replaced by UV disinfection.

Dichloromethane: The discharge does not have a reasonable potential to cause or contribute to an in-stream excursion above the water quality criteria. One possible source of dichloromethane is chlorination. Lower levels of dichloromethane may be observed in the future (reducing the reasonable potential levels) when the chlorination system is replaced by UV disinfection.

Chromium (VI): The discharge currently does not have a reasonable potential to cause or contribute to an in-stream excursion above the water quality objective by exceeding the CTR MCL for chromium (VI). Chromium (VI) is unlikely to be included in future NPDES permits if significant deviations from current conditions do not occur. The maximum effluent concentration of 0.6 µg/L is significantly lower than the current criteria (continuous maximum criteria is 16 µg/L and the secondary MCL is 50 µg/L).

Silver: The discharge currently does not have a reasonable potential to cause or contribute to an in-stream excursion above the water quality objective by exceeding the CTR MCL for silver. Silver is unlikely to be included in future NPDES permits if significant deviations from current conditions do not occur. The maximum effluent concentration of 3.2 µg/L is significantly lower than the current criteria (continuous maximum criteria is 8.6 µg/L and the BP objective is 10 µg/L).

Lead: The discharge currently does not have a reasonable potential to cause or contribute to an in-stream excursion above the water quality objective by exceeding the CTR MCL for lead. Lead

is unlikely to be included in future NPDES permits if significant deviations from current conditions do not occur. The maximum effluent concentration of 1.3 µg/L is significantly lower than the current criteria (secondary MCL is 15 µg/L and the continuous maximum criteria is 150 µg/L).

1,4 Dichlorobenzene: The discharge currently does not have a reasonable potential to cause or contribute to an in-stream excursion above the water quality criteria. 1,4-Dichlorobenzene is unlikely to be included in future NPDES permits if significant deviations from current conditions do not occur. The maximum effluent concentration of 0.8 µg/L is significantly lower than the current criteria (the secondary MCL is 5 µg/L).

Toluene: The discharge currently does not have a reasonable potential to cause or contribute to an in-stream excursion above the water quality criteria for toluene. Toluene is unlikely to be included in future NPDES permits if significant deviations from current conditions do not occur. The maximum effluent concentration of 0.7 µg/L is significantly lower than the current criteria (the secondary MCL is 150 µg/L).

MTBE: The discharge currently does not have a reasonable potential to cause or contribute to an in-stream excursion above the water quality criteria for MTBE. MTBE is unlikely to be included in future NPDES permits if significant deviations from current conditions do not occur. The maximum effluent concentration of 0.7 µg/L is significantly lower than the current criteria (the secondary MCL is 5 µg/L).

2.5 Comparison of Projected Effluent Quality With Probable Future Quality Limitations

Table 2-6 compares the projected effluent quality from the WQCF following completion of the Phase III Expansion Project to the probable future water quality limitations requirements. A discussion of potential compliance issues follows below. Compliance with limits considers three categories: 1) limits that can be achieved; 2) limits that may be achieved; and 3) limits that are unlikely to be achieved.

**TABLE 2-6
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
COMPARISON OF PROBABLE FUTURE WATER QUALITY LIMITATIONS
VERSUS PROJECTED EFFLUENT QUALITY
FOLLOWING PHASE III EXPANSION PROJECT**

Constituents	Units	Compliance Criteria	Probable Future Limit	Projected Effluent Median Concentration
BOD	mg/L	Monthly average	10 or lower	7
Total Suspended Solids	mg/L	Monthly average	10 or lower	< 10
Total Coliform	MPN/100 mL	Weekly average	2.2	< 2.2
Turbidity	NTU	1 Hour average	2	< 2
Settleable Solids	mg/L	Monthly average	0.1	0.1
Chlorine Residual	mg/L	4-day average	0.01	0.01
Oil and Grease	mg/L	Monthly average	10	2.1
Aluminum	µg/L	Monthly average	71	150
Electrical Conductivity	µmhos/cm	Monthly average	1000	825
Ammonia ^a	mg/L	Monthly average	2.1	1.5
Ammonia ^b	mg/L	Monthly average	2.8	1.5
Arsenic	µg/L	Monthly average	10	8
Copper	µg/L	Monthly average	7.9	7
Cyanide	µg/L	Monthly average	3.7	7
Iron	µg/L	Monthly average	300	47
Manganese	µg/L	Monthly average	50	15
MBAS	µg/L	Monthly average	500	560
Nitrate (as N)	mg/L	Monthly average	10	5
Nitrite (as N)	mg/L	Monthly average	1	1
Bis (2-ethylhexyl) phthalate	µg/L	Monthly average	22	3.48
Bromodichloromethane	µg/L	Monthly average	5	ND ^c
Dibromochloromethane	µg/L	Monthly average	1.4	ND ^c
2,4,6-Trichlorophenol	µg/L	Monthly average	34	3.28

^a June – September

^b October – May

^c Non-detect

a. Achievable Limits

The Phase III Expansion project, particularly Schedule D improvements, have been designed to reliably reduce constituent concentrations to typical tertiary treatment levels for BOD, total suspended solids, total coliform, turbidity, settleable solids, chlorine residual, oil and grease, ammonia, and nitrogen. These tertiary treatment goals are consistent with limitations in the current NPDES permit and subsequent revisions can be readily achieved.

b. Limits That May Be Achievable

Reductions in contaminants such as arsenic and electrical conductivity may occur as the result of source water quality improvements. Well head treatment planned for the City water supply network may also contribute to improvements in background water quality. These represent important considerations because the current treatment process proposed at the WQCF is not designed to accomplish removal of these constituents. As such, reliable compliance with NPDES limits can only be ensured based on the timing, extent, and effectiveness of alternate source water development.

c. Limits That Are Unlikely to Be Achieved

For metals and other organics, some reductions may occur as a by-product of the planned filtration-UV disinfection process in Schedule D based on historical performance at similar plants. Some cyanide reduction may be observed upon switching from chlorination to UV disinfection. Despite these potential reductions, compliance with the future NPDES limits for aluminum, cyanide, and MBAS will prove problematic. In general, because of the uncertainty in predicting removal efficiencies for metals and organics through the filtration process, consistent permit compliance with a number of the proposed effluent limits cannot be assured. Only membrane processes have demonstrated effective removal of dissolved contaminants for the levels identified in the current/future permit for surface water discharges.

2.6 Strategy for Future Compliance

Continued surface water discharge to the San Joaquin River represents a key component of the long-term wastewater management strategy for the City. For those constituent limits that may prove problematic such as aluminum, cyanide, and MBAS, continued sampling is recommended to better determine background levels and potential sources. Where appropriate, dissolved metal concentrations should be determined to then demonstrate no reasonable potential to exceed the BP objective. Additional data may demonstrate that constituent levels can be met through operational changes at the WQCF as may be the case for cyanide and MBAS. Where allowed by the RWQCB for aluminum and iron, site specific limits based on water effect ratio studies should be developed that better reflect BP objectives and the assimilative capacity of the receiving water. Site specific objectives are likely to be achieved for aluminum and iron based on historical effluent quality. The overall goal in terms of regulatory compliance should then be to implement pollution prevention programs (PPPs) that ensure continued discharge of filtered, disinfected effluent without the addition of membrane processes.

3 Projected Flow and Loadings

Anticipated future flow rates and loadings to the Manteca WQCF are presented below. Future average daily WQCF flows are predicted using General Plan land use information [4] and wastewater generation factors established for specific land uses. Future maximum daily and peak hourly WQCF flows are projected using peaking factors based on WQCF flow data in 2003. Projected flows are presented for Year 2023 (General Plan 20-year horizon) and buildout ultimate conditions.

3.1 Projected Flow

Wastewater generation factors (WGF) for various land uses are summarized in Table 3-1. Residential WGFs were calculated using the dwelling densities adopted in October 2003 [4]. Future average daily flows for each land use area are projected by multiplying the appropriate WGF with the land use area. As presented in Table 3-2, flows predicted for various land uses are then totaled to estimate the future contribution from the City of Manteca. Because of a contractual agreement between the Cities of Manteca and Lathrop, 14.7 percent of the WQCF capacity is made available for the treatment of Lathrop wastewater. Combined future Manteca and Lathrop flows are summarized in Table 3-3.

As presented in Table 3-3, future average wastewater flows for Manteca and Lathrop are anticipated at 19.5 mgd and 3.5 mgd in Year 2023, and 23 mgd and 4 mgd, at buildout, respectively. The total projected average wastewater flow to the WQCF is 23 mgd at Year 2023 and 27 mgd at buildout. Differences in flow from Year 2023 to buildout represent development within the Urban Reserve areas as detailed in the General Plan [4].

City of Manteca
Wastewater Quality Control Facility Master Plan
Chapter 3: Projected Flow and Loadings

TABLE 3-1
 CITY OF MANTECA
 WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
 WASTEWATER GENERATION FACTORS

Land Use	Designation	Density ^a (dwelling units/acre)	Wastewater Generation Factor ^b (gpd/acre)
Very low density residential	VLDR	Less than 2	530 ^c
Low density residential	LDR	2.1-8	1,338 ^d
Medium density residential	MDR	8.1-15	2,183 ^e
High density residential	HDR	15.1-25	3,789 ^f
Commercial mixed use	CMU	--	2,473
General commercial	GC	--	1,120
Heavy industrial	HI	--	2,010
Light industrial	LI	--	2,010
Public/Quasi-Public (P/QP)	PQP	--	425
Park	P	--	400
Agriculture	AG	--	0
Open space	OS	--	0
Neighborhood commercial	NC	--	1,120
Business industrial park	BIP	--	1,330 ^g
Urban reserve	UR	--	0
Very low density residential – urban reserve	UR-VLDR	--	530
Low density residential – urban reserve	UR-LDR	--	1,338
Medium density residential – urban reserve	UR-MDR	--	2,183
Commercial mixed use – urban reserve	UR-CMU	--	2,473
General commercial – urban reserve	UR-GC	--	1,120
Light industrial – urban reserve	UR-LI	--	2,010
Public/Quasi-Public – urban reserve	UR-PQP	--	425
Park – urban reserve	UR-P	--	400
Agriculture – urban reserve	AG-UR	--	0
Business industrial park – urban reserve	UR-BIP	--	1,330

^a Based on the adopted 2003 General Plan [4]

^b Nonresidential generation factors based on the 1993 Wastewater Collection Master Plan [5]

^c Generation rate based on 265 gpd/edu [6] and density of 2 dwelling units per acre

^d Generation rate based on 265 gpd/edu [6] and density of 5.05 dwelling units per acre

^e Generation rate based on 189 gpd/edu [6] and density of 11.55 dwelling units per acre

^f Generation rate based on 189 gpd/edu [6] and density of 20.05 dwelling units per acre

^g Generation rate assumed comparable to business park (office professional)

TABLE 3-2
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
PROJECTED WASTEWATER FLOWS – MANTECA ONLY
YEAR 2023 AND BUILDOUT CONDITIONS

Land Use	Area, Acres	Wastewater Generation Factor ^a (gpd/acre)	Wastewater Flow, mgd
VLDR	928	530	0.49
LDR	6,474	1,338	8.66
MDR	462	2,183	1.01
HDR	420	3,789	1.59
CMU	532	2,473	1.31
GC	893	1,120	1.00
HI	953	2,010	1.92
LI	1,048	2,010	2.11
PQP	1,124	425	0.48
P	536	400	0.21
AG	3,956	0	0
OS	438	0	0
NC	153	1,120	0.17
BIP	211	1,330	0.28
UR	<u>1,758</u>	0	<u>0</u>
Year 2023 (rounded)	19,890		19.5
UR-VLDR	996	530	0.53
UR-LDR	1,432	1,325	1.92
UR-MDR	20	1,701	0.04
UR-CMU	43	2,473	0.11
UR-GC	43	1,120	0.05
UR-LI	115	2,010	0.23
UR-PQP	12	425	0.005
UR-P	65	400	0.03
UR-AG	1789	0	0
UR-BIP	<u>425</u>	1,330	<u>0.57</u>
Buildout (rounded)	24,830		23.0

TABLE 3-3
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
PROJECTED WASTEWATER FLOWS

	Year 2023	Buildout
City of Manteca	19.5	23.0
City of Lathrop ^a	<u>3.5</u>	<u>4.0</u>
Total	23.0	27.0

^a Based on contractual agreement for 14.7% of total plant capacity.

Hydraulic peaking factors were estimated using 2003 WQCF flow data. Average daily total plant and Lathrop flows are shown in Figure 3-1. For reference, the ADWF in 2003 was 5.81 mgd. The maximum daily flow (MDF) was observed on October 5, 2003 at 7.86 mgd. This represents a daily peaking factor (MDF/ADWF) of 1.36.

Hourly flow rates observed for 15 day periods during February 2003, May 2003, August 2003, and November 2003 were used to establish hourly peaking factors (see Appendix A). A summary of seasonal hourly flow rates is provided in Table 3-4. The maximum hourly flow (MHF) was observed on November 19, 2003 at 15 mgd. The hourly peaking factor (MHF/ADWF) ranged from 1.98 to 2.58. For planning purposes, an hourly peaking factor of 2.19 is recommended, representing the greatest “average” peak hour condition observed. For reference, the design peak hour flow factor for the Phase III Expansion Project is 1.94.

TABLE 3-4
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
SUMMARY OF HOURLY FLOW RATES IN 2003


	Maximum Hourly Flows (mgd)			Hourly Peaking Factor		
	Average	Low	High	Average	Low	High
Winter ^a	11.54	7.50	12.50	1.98	1.29	2.15
Spring ^b	12.46	12.00	13.50	2.14	2.06	2.32
Summer ^c	12.32	8.00	14.00	2.12	1.38	2.41
Fall ^d	12.75	11.00	15.00	2.19	1.89	2.58

^a Based on WQCF flows between February 9, 2003 and February 22, 2003

^b Based on WQCF flows between May 11, 2003 and May 24, 2003

^c Based on WQCF flows between August 8, 2003 and August 24, 2003

^d Based on WQCF flows between November 9, 2003 and November 22, 2003



Date

FIGURE 3-1
 MANTECA WASTEWATER QUALITY CONTROL FACILITY
 MASTER PLAN UPDATE
 WQCF AVERAGE DAILY FLOW IN 2003

NOTE
 BEYOND ENGINEERING

Future maximum day and peak hour flows are estimated using the anticipated future average flows and the peaking factors discussed above. Future maximum daily flow and peak hourly flow are anticipated to be approximately 31.3 mgd and 50.1 mgd in Year 2023 and 36.7 mgd and 59.1 mgd at buildout, respectively. Influent flow rates observed in 2003 and anticipated future flow rates are summarized in Table 3-5.

**TABLE 3-5
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
SUMMARY OF WASTEWATER FLOWS (MGD)**

Parameter	2003	2023	Buildout
Average dry weather flow	5.81	23.0	27.0
Maximum daily flow	7.86	31.3	36.7
Peak hourly flow	15.0	50.1	59.2

^a Flows from cities of Manteca and Lathrop.

3.2 Projected Loadings


Wastewater loadings are a key parameter in the development of design criteria for a wastewater treatment plant. For the Manteca WQCF, wastewater loadings used in design are summarized in Table 3-6. Future average and peak organics (BOD), TSS, and ammonia loadings (loadings) are based on plant influent data from January 2002 through January 2004 and the anticipated future ADWF to the plant. Wastewater loadings are then compared with design criteria for the Phase III Expansion Project.

**TABLE 3-6
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
SUMMARY OF WASTEWATER LOADINGS USED FOR DESIGN PURPOSES**

Loading Parameter	Design Purpose
Average value	Quantify annual sludge production. Seasonal sludge production can also be estimated using average values. Estimate annual operational and maintenance requirements and costs.
Maximum monthly or 95th percentile (whichever is higher)	Design of biological treatment processes such as aeration basins considering 30-day NPDES permit requirements.
Maximum weekly	Check secondary treatment design criteria (developed based on maximum monthly or 95 th percentile values) and determine weekly effluent quality. Compare with 7-day NPDES permit requirements. Maximum weekly values would be used in design of secondary treatment facilities, if the ratio of maximum weekly to maximum monthly (or 95 th percentile) values exceed two.
Maximum daily	Design of waste activated sludge (WAS) thickening facilities. Design of secondary clarifiers and filtration facilities. Check secondary treatment design criteria (developed based on maximum monthly or 95 th percentile values) and determine daily effluent quality. Compare with maximum daily NPDES permit requirements. Maximum daily values would be used in design of secondary treatment facilities, if the ratio of maximum daily to maximum monthly (or 95 th percentile) values exceed three for BOD and TSS loading, and two for ammonia loading, respectively.

a. Future Average WQCF Loadings

Influent BOD, TSS, and ammonia concentrations from January 2002 through January 2004 are shown in Figures 3-2, 3-3, and 3-4, respectively. Average BOD, TSS, and ammonia concentrations during this period are 383 mg/L BOD, 340 mg/L TSS, and 34 mg/L ammonia, respectively. As a comparison, the design values for the Phase III Expansion Project are 310 mg/L BOD, 315 mg/L TSS, and 35 mg/L TKN. For reference, the Phase III Expansion Project design criteria reflect influent quality data for the period 1995-2000.



Data

FIGURE 3-2

MANTECA WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE

DAILY AVERAGE BOD DATA
FROM JANUARY 2002 THROUGH JANUARY 2004

NOITE
BEYOND ENGINEERING





FIGURE 3-3

MANTECA WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE

DAILY AVERAGE TSS DATA
FROM JANUARY 2002 THROUGH JANUARY 2004

NOI TE
BEYOND ENGINEERING



Data

FIGURE 3-4
 MANTECA WASTEWATER QUALITY CONTROL FACILITY
 MASTER PLAN UPDATE
 DAILY AVERAGE AMMONIA DATA
 FROM JANUARY 2002 THROUGH JANUARY 2004



The average influent BOD and TSS values were observed to increase 24 percent and eight percent (compared to the Phase III Expansion Project design values), respectively in 2002 and 2003. The peak influent BOD and TSS values were also observed to increase 28 percent and 38 percent, respectively in 2002 and 2003. Primary effluent TSS and BOD values obtained for 2002 and 2003 were compared to 2001 and 1991-1992 primary effluent data to investigate the increase in influent values in 2002 and 2003. TSS and BOD values are summarized in Table 3-7.

TABLE 3-7
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
COMPARISON OF HISTORICAL TSS AND BOD INFLUENT AND PRIMARY EFFLUENT VALUES

Period	Average TSS (mg/L)			Average BOD (mg/L)		
	Influent	Primary Effluent	Primary Removal Efficiency	Influent	Primary Effluent	Primary Removal Efficiency
1991 - 1992	221	68	69%	262	178	32%
2001	278	105	62%	319	229	28%
January 2002 - December 2003	333	99	70%	376	234	38%

The following conclusions are offered from a review of the results presented in Table 3-7:

1. Average influent BOD and TSS increased 22 percent and 26 percent, respectively between 1991-1992 and 2001. Primary effluent BOD and TSS increased 29 percent and 54 percent, respectively. The increases in primary effluent BOD and influent BOD are consistent (22 percent versus 29 percent). The increase in primary effluent TSS is higher compared to the increase in influent TSS (54 percent versus 26 percent). This suggests a possible error in any one of the following measurements: (1) 1991 influent or primary effluent TSS or (2) 2001 influent or primary effluent TSS values.
2. Primary effluent values seem to remain unchanged from 2001 to 2002-2003. This suggests that measured influent TSS and BOD values observed in 2002 and 2003 may be higher (up to 20 percent) than the actual values. Therefore, 10 percent reduction in measured 2002 and 2003 BOD and TSS values is deemed to be appropriate for design purposes, as discussed below.

Based on a future flow of 27 mgd (ADWF), average loadings are presented in Table 3-8 considering the 10 percent reduction in 2002 and 2003 BOD and TSS values. Specifically, at buildout the anticipated average BOD, TSS, and ammonia loadings will be 78,400 lb/day, 70,000 lb/day, and 7,600 lb/day, respectively.

**TABLE 3-8
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
ANTICIPATED FUTURE LOADING AT PLANT BUILDOUT**

	BOD	TSS	Ammonia
Influent Concentrations, mg/L ^a			
Average	348	309	34
Maximum monthly	501	592	41
95th percentile	506	511	44
Maximum weekly	614	780	46
Maximum daily	1,013	1,229	56
Influent Loads, lb/day ^b			
Average	78,400	70,000	7,600
Maximum monthly	113,000	133,500	9,200
95th percentile	114,000	115,000	10,000
Maximum weekly	138,500	176,000	10,500
Maximum daily	228,500	277,000	12,700
Peaking Factors			
Maximum monthly / average	1.44	1.91 ^c	1.21
95 th percentile / average	1.46 ^d	1.65	1.30 ^d
Maximum weekly / average	1.77	2.52	1.38
Maximum daily / average	2.91	3.98	1.66
Maximum weekly / maximum monthly ^e	1.23	1.32	1.14
Maximum weekly / 95th percentile ^e	1.21	1.53	1.06
Maximum daily / maximum monthly ^f	2.02	2.08	1.38
Maximum daily / 95th percentile ^f	2.00	2.41	1.27

^a Based on WQCF data from January 2002 through January 2004 (after 10 percent reduction)

^b Based on WQCF influent concentration data (10 percent reduction) from January 2002 through January 2004 and anticipated future ADWF of 27 mgd

^c TSS design peaking factor (maximum monthly peaking factor >95th percentile peaking factor).

^d BOD and ammonia design peaking factor

^e Ratio is less than 2. Therefore, use of maximum monthly TSS value and 95th percentile values for BOD and ammonia in design of secondary treatment facilities is appropriate

^f Ratio is less than 3 for BOD and TSS and less than 2 for ammonia. Therefore, use of 95th percentile values for BOD and ammonia and maximum monthly TSS value in design of secondary treatment facilities is appropriate

b. Peaking Factors

Concentration peaking factors were calculated using influent BOD, TSS, and ammonia concentrations from January 2002 through January 2004 (see Figures 3-2, 3-3, and 3-4). Loading peaking factors were also calculated using the influent concentrations and flow rates observed in 2002 and 2003. Loading peaking factors and concentration peaking factors were of similar magnitude. Concentration peaking factors were slightly higher. Therefore for master planning purposes, concentration peaking factors will be used for facility sizing.

A summary of peaking factors is presented in Table 3-9. As discussed in Table 3-6, either peaking factors based on 95th percentile values (value larger than 95 percent of all observed values) or maximum monthly (maximum 30-day running average) values, or a combination of both parameters, are used typically in design of secondary treatment processes. The 95th percentile peaking factors for BOD (1.46) and ammonia (1.30) are slightly larger than the monthly peaking factors and therefore will be established as the design peaking factors for BOD and ammonia. As seen in Table 3-9, the monthly peaking factor for TSS (1.91) is larger than the 95th percentile peaking factor (1.65) and therefore will be used as the design peaking factor for TSS. As a comparison, the design peaking factors for the Phase III Expansion Project are 1.4, 1.5, and 1.8 for BOD, TSS, and TKN respectively. As discussed above, peaking factors based on influent values are 1.46 and 1.91 for BOD and TSS, respectively. Monthly peaking factors based on primary effluent values are also presented in Table 3-9. The recommended peaking factors for the design of secondary treatment facilities are then given in Table 3-9. These peaking factors represent a conservative approach to facility sizing without excessive oversizing of individual unit pressures.

**TABLE 3-9
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
SUMMARY OF PEAKING FACTORS TO BE USED IN THE
DESIGN OF SECONDARY TREATMENT FACILITIES**

	Phase III Expansion- Peaking Factors	Influent Peaking Factors ^a	Primary Effluent Peaking Factors ^b	Recommended Secondary Treatment Design Peaking Factor ^c
BOD	1.4	1.46	1.29	1.4
TSS	1.5	1.91	1.46	1.7

^a Based on 2002-2003 influent BOD and TSS data

^b Based on 2002-2003 primary effluent BOD and TSS data

^c Obtained by averaging the influent and primary effluent peaking factors. Peaking factors are then rounded.

c. Future Peak WQCF Loadings

Recommended peaking factors and anticipated future average loadings discussed previously are used to estimate the future peak loadings. As presented in Table 3-10, future maximum monthly BOD, TSS, and ammonia loadings are expected to be 114,000 lb/day, 133,500 lb/day, and

10,000 lb/day, respectively. Maximum daily BOD, TSS, and ammonia loadings are anticipated to be 228,000 lb/day, 279,000 lb/day, and 13,000 lb/day, respectively. As mentioned above, maximum daily values are considered in design of waste activated sludge (WAS) thickening and tertiary filtration facilities. Design values for primary and secondary treatment processes are summarized in Table 3-10.

**TABLE 3-10
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
SUMMARY OF ANTICIPATED FUTURE LOADINGS AT BUILDOUT**

Constituent	Peaking Factor	Loading	
		Average	Peak
Primary Treatment Processes			
BOD	1.46	78,400	114,000
TSS	1.91	70,000	133,500
Ammonia	1.30	7,600	10,000
Secondary Treatment Processes			
BOD	1.40	78,400	110,000 ^a
TSS	1.70	70,000	119,000 ^a
Ammonia	1.30	7,600	10,000 ^a
WAS Thickening/Tertiary Filtration			
BOD	2.91	78,400	228,000 ^b
TSS	3.98	70,000	279,000 ^b
Ammonia	1.66	7,600	13,000 ^b

^a Maximum monthly or 95th percentile

^b Maximum daily

4 Effluent Disposal Strategies

The long-term recommended disposal strategy for the City WQCF is presented below. Treated effluent from the WQCF would be disposed of by three methods: 1) On-site land application; 2) Urban landscape irrigation; and 3) Discharge to the San Joaquin River. Off-site land application through an expanded agricultural irrigation program is not considered feasible because of the magnitude of the required land acquisition (greater than 5,000 ac) and the potential distance from the plant. The WQCF currently discharges to the San Joaquin River or on-site land application. A combination of the three disposal methods will be utilized to discharge the buildout flow of 27 mgd. Each disposal strategy, and the amount of treated effluent that can be discharged by that method, are described below and summarized in Table 4-1.

4.1 On-Site Land Application

The City currently discharges approximately 1030 ac-ft/yr (0.87 mgd) of undisinfected secondary effluent to 190-ac of City-owned land. An existing 9-ac, 15-Mgal storage pond located on City land immediately west of the WQCF is used in the on-site land application system. The City is planning to develop 30-ac of City-owned land for a state of the art softball complex, leaving 160-ac of City-owned land available for on-site land application.

The permeability of soils identified at the on-site land application area ranged from moderately rapid to rapid [7]. The hydraulic loading at the WQCF is generally between 65 and 70 inches per year. Assuming an application rate of 65 inches per year on the remaining 160-ac of City-owned land, approximately 0.73 mgd of treated effluent can be disposed of by on-site land application.

4.2 Urban Landscape Irrigation

The technical memorandum *Evaluation of Urban Water Recycling Opportunities from the Manteca Wastewater Quality Control Facility* [8] investigates the use of urban landscape irrigation to dispose of treated effluent from the WQCF. The technical memorandum identifies 741-ac of irrigable urban land. This information has subsequently been updated, and a total of 817-ac of irrigable urban land have been identified, including parks, schools, cemeteries, and golf courses [9]. Assuming an application rate of 54 in/yr, 3.28 mgd of recycled water would be discharged for urban landscape irrigation (see Appendix B).

It should be noted that unrestricted urban irrigation with recycled water requires the production of tertiary disinfected recycled water as defined by the DHS. This water quality requirement will be satisfied upon completion of the Phase III Expansion Project. To reduce the potential for public contact with recycled water, parks, schools, and cemeteries are assumed to be irrigated between 10 p.m. and 6 a.m. (This limited window for landscape irrigation is a typical DHS requirement.) The golf courses are assumed to receive water 24-hours per day.

4.3 River Discharge

The City is currently permitted to discharge 8.11 mgd to the San Joaquin River under NPDES Permit No. CA0081558 [2]. The permit allows the monthly average discharge to increase to 9.87 mgd in February 2009, provided that additional water quality requirements are satisfied by the WQCF. The increase in flow to 9.87 mgd will be discharged to the San Joaquin River through the existing 36-inch outfall. Due to concerns of thermal impacts to the San Joaquin River, the WQCF will likely be restricted from discharging during reverse flow events. Beyond 9.87 mgd ADWF, a second parallel outfall will be required to convey the balance of WQCF effluent either not land applied on-site or pumped off-site for urban irrigation. A discussion of the routing of the parallel 36-inch land outfall is presented in Appendix C.

**TABLE 4-1
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
RECOMMENDED DISPOSAL STRATEGY AT BUILDOUT**

Disposal Option	Average Discharge Rate, mgd	Annual Volume, ac-ft/yr	Percentage of Total Discharge
On-Site Land Application	0.73	870	3%
River Discharge	22.99	25,760	85%
Urban Landscape Irrigation	3.28	3,670	12%
Total	27.00 ^a	30,300	100%

^aBased on anticipated wastewater flow to Manteca WQCF, see Chapter 3.

5 Odor Control

To develop an odor control strategy at the Manteca WQCF, it is important to understand historical odor control practices, potential odor sources, and odor control alternatives. Each topic is discussed below.

5.1 Historical Odor Control Practices

The historical odor control practice at the WQCF focused on reducing the dissolved sulfide concentration in the wastewater prior to the generation and release to the air of hydrogen sulfide (H_2S). Air was introduced to the influent trunk sewer via a blower at the influent pump station to move any odorous air away from the plant, considering the facility has no provisions to reduce or remove H_2S once it has been released to the atmosphere. The Manteca WQCF began using ferric chloride for hydrogen sulfide control in the spring of 1996. The typical dosage was 1-3 mg/L. The ferric chloride was stored in a 6,500 gal portable tank near the septage receiving station and was added to the 36-in. North Manteca Trunk Sewer using a chemical metering pump. Dosage was usually manually adjusted with no automatic pacing. To avoid overdosing during low flow periods, chemical addition was discontinued from 12 a.m. to 6 a.m. typically each day. The combined practice of ventilation and the addition of ferric chloride proved relatively effective in reducing odors at the plant although chemical augmentation was suspected in the accelerated deterioration of influent pump impellers.

5.2 Potential Odor Services

Field investigations and wastewater sampling later confirmed the high potential for H_2S odor generation at the Manteca plant. With the facility sited several miles from either the Lathrop or Manteca collection systems, detention times are long in trunk sewers and force mains, particularly during periods of low flow. Significant concentrations of hydrogen sulfide have been detected at the plant and future design conditions will likely not mitigate these existing problems. Because the new influent pump station constructed as part of the Phase III Expansion Project must accommodate buildout flows hydraulically, during current low flows, there may be drops in water surface elevations that contribute to off-gassing. With the new headworks/influent pump station constructed immediately adjacent to the easterly property line, there is little room for error in terms of odor dissipation. The large volume of air that must be circulated and vented from the pump station represents a significant source of odorous air that left untreated would likely lead to neighbor complaints. Considering these factors and the desire not to impact adjacent future development potential adversely, particularly with a new City softball complex, an odor control system is recommended for installation with the headworks/influent pump station and primary sedimentation basins.

5.3 Discussion of Odor Control Techniques

Ferric chloride additions have been successful in reducing the dissolved H_2S concentrations in raw wastewater entering the plant. Expansion of the ferric chloride application program further

upstream within the wastewater collection system (e.g., Union Road Pump Station) or at the Lathrop O Street pump station could help mitigate odor potential at the Manteca WQCF. However, considering the future re-routing of the Lathrop force main to a junction structure with the North Manteca Trunk Sewer, the range of flows and hydraulic conditions anticipated at the headworks/influent pump station, and the long detention times in the collection system, ferric chloride addition alone, will likely not be sufficient to control odors. Other odor control techniques therefore should be assessed as follows.

a. Description of Alternatives

There are three principle types of odor control techniques that have been used successfully for many years at wastewater treatment plants and numerous hybrid or experimental strategies that have a limited track record. This assessment will be limited to the three most common systems:

1. Packed Tower Scrubbing
2. Mist Scrubbing
3. Soil Filter

Packed Tower Scrubbing: Packed tower scrubbing relies on chemicals to react with the odor compounds found in the air collected from the process area. The packed tower is a vertical tank, usually constructed of fiberglass, that contains a bed of plastic packing sized from 1 in to 3 in. in nominal diameter. The chemical solution (sodium hydroxide) is pumped to the top of the media and flows over the large surface area of the media in a thin sheet. This creates a large surface area for the odor molecules to come in contact and react with the chemical solution. The air is drawn into the bottom section of the vertical tower with a fiberglass duct axial fan and exhaust is vented out the top of the tower.

The application rate of the chemical solution can be based on the pH and oxidation reduction potential of the liquid after it has passed over the plastic media and reacted with odor compounds. The chemical solution is collected in a sump and is pumped back over the top of the media. A portion of the chemical solution is routinely wasted and replaced with fresh solution to prevent a buildup of waste products.

Mist Scrubbing: The mist scrubbing system is similar to the packed tower in that it relies on a chemical solution and a large surface area on which the odor molecule can react with the chemical solution. In this technique the large surface area is achieved by creating a fine mist of the chemicals. The mist droplets have a high surface area to volume ratio. The nozzle that creates the mist has a very small opening. To avoid plugging the small nozzle opening with impurities from the foul air stream, the chemical solution comes in contact with the foul air only once. There is no recycling of the chemical solution. The spent solution is discharged to the wastewater stream.

The feed rate of the chemical solution is based upon the air flow rate and the concentration of the odor compounds in the foul air. Matching these two parameters requires a more complicated chemical feed and control system than the packed tower alternative. The removal efficiency of the mist scrubbing system is reduced by high and fluctuating levels of hydrogen sulfide.

Soil Filter: The soil filter, or biofilter, relies on bacteria in either wet compost, soil, or an engineered medium to remove the majority of the odor compound without the need to use large quantities of chemicals. The foul air is blown through the bottom of the soil filter through a distribution system of perforated pipe and as the air comes in contact with the bacteria, the hydrogen sulfide and other odor compounds are consumed. Water sprayed on top of the compost, soil, or engineered medium maintains the correct moisture for high odor removal rates. The byproduct produced by the bacteria is acidic, so the pH of the media decreases with use. A small quantity of neutralizing chemicals can be applied to keep the soil filter pH in the optimum range for removing odor compounds. The typical sizing criteria for biofilters is 0.5 ft² soil filter/cfm of air flow. Based on the required air flow of 13,000 cfm, a minimum 6,500 ft² biofilter would be necessary for odor control at the influent pump station. Soil filters are well suited for applications that require low air flow rates (1,500 cfm or less). Operational problems such as uneven air distribution and short circuiting have been reported at rates above 1,500 cfm, however, many large scale installations (greater than 10,000 cfm) have successful track records.

b. Comparison of Odor Control Techniques

With minimal mechanical equipment, the biofilter option represents the least capital investment although the first costs for the packed tower scrubber are not significantly greater. The wide divergence in costs between the options occurs when considering operation and maintenance requirements. Both the packed tower and mist scrubber systems rely upon the use of chemicals that create significantly higher annual costs than the biofilter. Considering this difference in annual costs, the biofilter alternative is the lowest cost option on a life-cycle basis. In view of this comparison, biofilters are recommended for odor control at the WQCF.

6 Solids Handling Practices

A discussion of solids handling practices of the WQCF is presented in this chapter. Projected loadings and disposal strategies are described below.

6.1 Description of Solids Handling Facilities

Solids handling facilities include sludge thickening, sludge digestion, and sludge dewatering. Each unit process is discussed below along with projected loadings at buildout.

a. Sludge Thickening

Dissolved air flotation (DAF) will be used for the thickening of the waste activated sludge (WAS) produced in the secondary treatment facilities. The primary purpose of DAF is to reduce the liquid volume of WAS. Waste activated sludge and thickened waste activated sludge (TWAS) data observed at the Manteca WQCF between January 2003 and March 2004 were used to project the WAS and TWAS rates at buildout conditions. Dissolved air flotation units are designed for the observed TWAS flow daily peaking factor of 3.29. Average WAS and TWAS production at buildout is approximately 19,800 lb/day and 17,800 lb/day, respectively. Projected average and peak WAS and TWAS rates are summarized in Table 6-1. Peaking factors observed for the WAS rates were lower than the peaking factors observed for the TWAS rates. Observed TWAS peaking factors are used for planning purposes.

**TABLE 6-1
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
PROJECTED SOLIDS LOADING AT BUILDOUT**

		Primary Sludge (PS)	Waste Activated Sludge (WAS)	Thickened Waste Activated Sludge (TWAS)	Combined PS & TWAS (CS)
Peaking Factors					
Peak day	ratio	4.71	3.29	3.29	3.91
15 day peak	ratio	1.78	1.96	1.96	1.56
Production					
Average	lb/day	27,100	19,800	17,800	44,900
Daily peak	lb/day	127,400	65,000	58,500	185,900
15 day peak	lb/day	48,300	38,700	34,800	83,100
Flow					
Average	gpd	93,300	525,300	48,100	141,400
Daily Peak	gpd	439,100	1,730,400	158,300	597,400
15-Day Peak	gpd	166,200	1,029,800	94,200	260,400

b. Sludge Digestion

Sludge generated in the primary sedimentation basins and TWAS will be stabilized in the anaerobic digesters. The purpose of the anaerobic digestion process is to reduce the mass of solids, to stabilize the organic material, to reduce the pathogen content of the solids, and to produce a combustible gas that can be used for sludge heating and electricity generation. Primary sludge (PS) and TWAS data observed at Manteca WQCF between January 2003 and March 2004 were used to project the combined sludge (CS) rates to the anaerobic digesters at buildout conditions. Average PS and CS production for the expansion is anticipated to be approximately 27,100 lb/day and 44,800 lb/day, respectively.

Due to the relatively long detention times within the digesters, a 15 day peaking factor is recommended for sizing of the digestion facilities. Therefore, the observed 15 day peaking factor of 1.56 for the CS flow will determine the volume of any new digestion. Projected average and peak PS and CS loadings are also presented in Table 6-1.

c. Sludge Dewatering

High solids centrifugal dewatering systems will be used to dewater digested sludge. These systems have the following major advantages as compared to other dewatering alternatives: (1)

they produce the highest solids content sludge and (2) they have the least operational and maintenance requirements. Polymer will be injected into the sludge feed line to enhance the dewatering process.

Dewatered cake from the centrifuges will be discharged at a solids content of approximately 25 percent onto a solids handling conveyor. The conveyor will discharge cake to a biosolids composting and storage area. The discharge of the conveyor will be located at a height that can accommodate truck loading if the City elects to haul biosolids off site at a future time.

The centrifuges will be operated Monday through Friday approximately 10 hr/day for average conditions. The centrifuges will be operated Monday through Saturday approximately 16 hr/day during peak sludge production. To store digester effluent generated during the weekends and non-working weekday hours, construction of an equalization tank as part of the dewatering process is recommended.

Centrifuge centrate (the liquid discharge) will flow by gravity to a centrate equalization transfer structure located adjacent to the dewatering process building. From the transfer structure, the centrate will be discharged to a centrate equalization tank.

The purpose of the centrate equalization tank is to reduce shock loading of centrate to the biological treatment processes. Based on historical laboratory analyses of the decant from the existing sludge drying beds, it is projected that the centrate may have a TKN concentration ranging from 600-1,000 mg/L. At this concentration, if no equalization were provided, the centrate would increase the incoming nitrogen loading significantly. This shock loading would make consistent operation of the secondary biological treatment system difficult. With equalization, the centrate will be released back to the headworks at a constant rate minimizing potential shock loading.

6.2 Biosolids Disposal

Biosolids generated currently at the existing and Phase III expansion facilities will continue to be reused beneficially on the City-owned land surrounding the plant in an agronomic application. Due to concerns regarding the potential generation of odors from a biosolids stockpile, the solids handling facilities for the Phase III expansion are designed to facilitate truck loading for subsequent off-site disposal. Biosolids generated from the ultimate (27 mgd) facility will be disposed at an off-site landfill.

7 Recommended Facility Improvements

Wastewater treatment facilities designed to meet the anticipated water quality objectives described in Chapter 2 are discussed in this chapter. A site plan at buildout is included as Figure 7-1. Design criteria are presented typically for the incremental expansion required to increase the facility capacity from 10.0 to 27.0 mgd. Overall hydraulic loading and solids loading criteria are summarized in Tables 7-1 and 7-2. Individual unit processes and design criteria are discussed as follows.

TABLE 7-1
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
DESIGN CRITERIA FOR PLANT EXPANSION
HYDRAULIC LOADING

Parameter	Unit	Buildout	Incremental Expansion
Flow			
Average dry weather flow, MGD	mgd	27.0	17.5
Maximum daily flow	mgd	36.7	23.8
Peak hourly flow	mgd	59.2	38.4





FIGURE 7-1
MANTECA WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE
 SITE PLAN AT BUILDOUT

NOLTE
 BEYOND ENGINEERING

BOUNDARY LINE FOR FIELD #1

**TABLE 7-2
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
DESIGN CRITERIA FOR INCREMENTAL PLANT EXPANSION
SUMMARY OF INFLUENT LOADINGS**

Parameter	Unit	BOD	TSS	Ammonia
Influent Concentrations				
Average	mg/L	348	309	34
Maximum monthly	mg/L	501	592	41
Maximum weekly	mg/L	614	780	46
Maximum daily	mg/L	1,013	1,229	56
95th percentile	mg/L	506	511	44
Influent Loads (Total at Buildout)				
Average	lb/day	78,400	70,000	7,600
Maximum monthly	lb/day	113,000	133,300	9,200
Maximum weekly	lb/day	138,500	176,000	10,500
Maximum daily	lb/day	228,500	277,000	12,700
95th percentile	lb/day	114,000	115,100	10,000
Influent Loads (Incremental Expansion)^a				
Average	lb/day	50,800	45,500	5,000
Maximum monthly	lb/day	73,300	86,400	6,000
Maximum weekly	lb/day	89,800	114,100	6,800
Maximum daily	lb/day	148,200	179,500	8,200
95th percentile	lb/day	73,900	74,600	6,500

^a Incremental expansion represents the difference between buildout and Phase III values.

7.1 Influent Pump Station/Mechanical Screening

As part of several long-term infrastructure improvements, the City is constructing two new trunk sewers to serve the north and south areas of the community, respectively. The new trunk sewers will be sized to convey the projected buildout flow of the community. Modification of the existing influent pump station to receive future flows was not economically or technically feasible due to the lower inverts of the new trunk sewers and the physical space limitations associated with the existing pump station. Therefore, a new influent pump station will be constructed as part of the Phase III improvements.

The influent pump station is sited on the easterly perimeter of the WQCF property to allow for easy tie-in with the new trunk sewers while minimizing disruption to existing facilities and structures. The station includes two mechanical screens, a wet well, a dry well equipped with

four centrifugal pumps, and a flow meter. Two fine mechanical screens (3/8 inch openings) are designed to remove coarse solids and non-biodegradable materials such as plastics. Removal of these materials will protect the influent pumps and subsequent downstream equipment as well as improve the quality of the biosolids produced at the plant (i.e., plastics in biosolids are highly undesirable when applied as a soil conditioner). Space is provided for a third mechanical screen for the buildout plant conditions.

Four screw centrifugal pumps will deliver screened raw wastewater to the NSF and SSF, respectively. Discharge from two 100-hp pumps will be conveyed to the NSF. Discharge from one 200-hp pump will be conveyed to the SSF. Through the operation of valves, a standby 200-hp pump can discharge to either the NSF or SSF. Space is provided in the influent pump station to install four additional pumps to handle projected future flows. Screw centrifugal pumps were selected because of their ability to pass solids and their high efficiency. Odor control will be accomplished by routing foul air to a central biofilter.

7.2 Grit Removal/Primary Sedimentation

Seven aerated grit tanks and ten primary sedimentation basins are proposed for the incremental expansion of the SSF headworks and primary treatment unit processes.

a. Aerated Grit Tanks

The purpose of the grit tanks is to remove relatively high density inorganic particles (e.g., sand) from the wastewater stream, thus reducing wear and tear on downstream equipment. The grit tanks were sized to provide sufficient detention time to allow the separation of the grit from the wastestream. Typical detention times in aerated grit tanks range from 2 to 5 minutes at peak flow [9].

The proposed grit tanks for the expansion facilities are designed with a 4 minute detention time at the peak flow (3.5 minutes with one unit out of service) as summarized in Table 7-3.

**TABLE 7-3
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
DESIGN CRITERIA FOR INCREMENTAL PLANT EXPANSION
AERATED GRIT TANKS**

Parameter	Unit	Value	Average Conditions	Peak Conditions
Number of new tanks	no	7		
Number of Phase III SSF tanks	no	2		
Length	ft	24		
Width	ft	8		
Depth (nominal)	ft	10.5		
Detention time	min		8.7	4.0
Detention time (one unit out of service)	min		7.7	3.5
Airflow, total	cfm		840	840

The 3:1 length to width ratio of the grit tanks (24 ft long x 8 ft x 10.5 ft deep) along with the placement of coarse bubble aerators along one side of the tank creates a spiral flow pattern resulting in the separation of the heavy grit particles from the wastewater. Recommended aeration rates in aerated grit tanks range from 3 to 8 cfm/ft of length [9]. A total airflow of 840 cfm to the grit tanks is suggested to supply an aeration rate of 5 cfm/ft.

Once separated from the wastewater, grit will settle into the hoppers in the bottom of the tanks. Grit collected in the hoppers will be discharged to a grit classifier by gravity for further concentration and washing of light organic material trapped with the grit. Concentrated and washed grit discharged from the classifier will be conveyed into a dumpster and periodically hauled to the landfill for disposal. Wash water from the classifier will be discharged into the plant drain system and returned to the influent pump station (IPS).

b. Primary Sedimentation Basins

The purpose of the primary sedimentation basins (PSBs) is to remove settleable solids and floatable scum, usually oil and grease. This is accomplished by providing a quiescent environment where particles with densities greater than water can settle and those with densities less than water will float to the surface.

The design of PSBs can be based on detention time or overflow rates. Recommended detention times for PSBs are 1.5 to 2.5 hours [11]. Typical overflow rates range from 800 to 1,200 gpd/ft² under average flow to 2,000 to 3,000 gpd/ft² under peak flow conditions [9]. Detention times and overflow rates for the PSBs are presented in Table 7-4. It can be seen in Table 7-4 that the detention time and overflow rates in the proposed PSBs will range from 1.2 to 2.8 hours and 776

to 1,842 gpd/ft² depending upon the flow regime and number of basins in service. While under certain conditions detention times in the PSBs are slightly below recommended values, overflow rates, a more critical indicator of process performance, always fall within the suggested criteria. To mitigate potential odors, the PSBs will be covered, with foul air routed to a local biofilter.

**TABLE 7-4
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
DESIGN CRITERIA FOR INCREMENTAL PLANT EXPANSION
PRIMARY SEDIMENTATION BASINS**

Parameter	Unit	Value	Average Conditions	Peak Conditions
BOD removal in PSBs	percent	30		
TSS removal in PSBs	percent	60		
Overflow rate, all PSBs in service	gpd/ft ²		776	1,700
Overflow rate, one PSB out of service	gpd/ft ²		841	1,842
Number of Phase III SSF PSBs	no	3		
Number of new PSBs	no	10		
Length to width ratio	ratio	5.4		
Length of each PSB	ft	110		
Width of each PSB	ft	20		
Total area of PSBs	ft ²	22,544		
Water depth	ft	12		
Detention time	hr		2.8	1.3
Detention time (one PSB out of service)	hr		2.6	1.2

7.3 Aeration Basins with Anoxic Zone

Seven new aeration basins, each rated for an average flow rate of 2.50 mgd are proposed. Each basin is approximately 126 ft long, 92 ft wide, with a side water depth of 17 ft. Each basin is divided into five zones, separated by baffle walls. The baffle walls create a serpentine flow pattern reducing the potential for hydraulic short-circuiting. The basins will be operated in a plug flow fashion with an initial anoxic zone, followed by four aerated zones. The ratio of the anoxic zone to the total volume is approximately 23 percent.

Carbonaceous BOD removal and nitrification will be accomplished in the aerated zones. Nitrified wastewater will be recirculated back to the first anoxic zone for nitrate removal, which is known as the modified Ludzack-Ettinger (MLE) process. Without aeration, the first zone in each basin will become anoxic. Under anoxic conditions, nitrate produced in the aerated zones will be reduced to nitrogen gas to achieve the required degree of total nitrogen removal. Other

benefits of an initial anoxic zone include the recovery of alkalinity consumed during nitrification and suppressing the growth of filamentous bacteria. The design of the aeration basin was based on cold weather conditions to consider worst case conditions. As seen in Table 7-5 for cold weather conditions, internal recirculation ratio varies between approximately 290 percent for average load conditions to 410 percent during peak load conditions. Typical internal recirculation ratios for MLE processes vary between 200 and 400 percent. Internal recirculation pumps will be sized for a flow rate of 11.5 MGD for each aeration basin to accommodate peak flow rates.

Other important criteria for the design of BOD and nitrogen removal facilities include hydraulic retention time (HRT), mean cell residence time (MCRT), activated sludge production, mixed liquor suspended solids concentration (MLSS), and specific denitrification rate. As seen in Table 7-5, the HRT values range from 6.1 to 14.2 hours (depending on the flow regime and number of basins in service), well within the recommended range of 5 to 15 hours for MLE processes. The minimum suggested MCRT values to achieve complete nitrification for the temperatures observed at WQCF are 6 days and 12 days during warm weather and cold weather, respectively. As presented in Table 7-5, the MCRT values range from 12 days to 15 days (depending on loading conditions) satisfying the minimum suggested values for cold weather period. The sludge yield coefficient during cold weather was estimated to be approximately 0.28 and was used to calculate the activated sludge production in the aeration basins. Average activated sludge production (during cold weather) in the aeration basins varies between approximately 15,000 lb/day and 24,000 lb/day depending on loading conditions. Typical MLSS concentration in MLE processes ranges between 3,000 and 4,000 mg/L. The MLSS concentration is assumed to vary between 3,000 mg/L and 4,300 mg/L for average and peak loading conditions, respectively at Manteca WQCF. The specific denitrification rate was calculated to be 0.28 lb of nitrate conversion for lb of active MLSS concentration in the anoxic zone (in a day). Active MLSS concentration in the anoxic zone was calculated to vary between approximately 820 mg/L and 1,140 mg/L for the other MLE process design criteria presented above. Total oxygen requirement was calculated to vary between approximately 63,000 lb/day and 84,500 lb/day (depending on the loading conditions) as presented in Table 7-5.

**TABLE 7-5
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
DESIGN CRITERIA FOR INCREMENTAL PLANT EXPANSION
AERATION BASIN**

Parameter	Unit	Value	Average Conditions	Peak Conditions
Aerated Zone				
BOD design peaking factor	ratio			1.4
TSS design peaking factor	ratio			1.7
Ammonia design peaking factor	ratio			1.3
Organic nitrogen conversion factor	ratio	1.15		
BOD concentration to aeration basin	mg/L		244	341
TSS concentration to aeration basin	mg/L		124	210
Ammonia concentration to aeration basin	mg/L		39	50
BOD filtrate return concentration	mg/L	600		
Ammonia filtrate return concentration	mg/L	100		
Assumed sludge filtrate return flow	gpm	200		
BOD to aeration basins	lb/day		36,500	50,800
Ammonia to aeration basins	lb/day		6,000	7,700
BOD removal in secondary	percent	97		
Ammonia removal in secondary	percent	100		
TSS removal in secondary	percent	80		
Solids retention time	day		15.0	12.0
MLSS concentration	mg/L		3,000	4,300
Return activated sludge ratio	percent		50	60
TSS volatile fraction	percent	80		
TSS volatile biodegradable fraction	percent	67		
Yield coefficient-heterotrophic	gVSS/gBOD	0.28		
Decay coefficient-heterotrophic	1/day	0.10		
Yield coefficient-autotrophic	gVSS/gAmmonia	0.12		
Decay coefficient-autotrophic	1/day	0.06		
Fraction cell debris	percent	0.15		
Total activated sludge production	lb/day		14,600	23,800
Nonbiodegradable VSS and inert TSS portion	lb/day		6,696	11,384
Aerated volume	MG	8.0		
Detention time (aerated zone)	hr		10.9	5.0
Number of aerated compartments	no	4		

**TABLE 7-5 (CONTINUED)
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
DESIGN CRITERIA FOR INCREMENTAL PLANT EXPANSION
AERATION BASIN**

Parameter	Unit	Value	Average Conditions	Peak Conditions
Aerated Zone (cont.)				
Oxygen requirement				
For BOD	lb-oxygen/lb-load	1.0		
For Ammonia	lb-oxygen/lb-load	4.6		
Total oxygen requirement	lb/day		63,000	84,500
Volumetric BOD loading	lb BOD/1,000 ft ³ -day		25	37
Recycle ratio	percent		50	60
Food to microorganism ratio	1/day		0.20	0.22
Anoxic zone				
Ratio of anoxic zone volume	percent	23		
Volume	MG	2.4		
Detention time	hr		3.3	1.5
Nitrate to anoxic zone	mg/L		35.3	45.7
Effluent nitrate	mg/L	8.0		
Internal recycle ratio for denitrification	percent		291	411
Influent nitrate load to the anoxic zone	lb/day		4,000	5,500
Anoxic zone active biomass, mg/L	mg/L		820	1,150
Food to active microorganism ratio	1/day		2.2	2.2
Specific denitrification rate	lb NO ₃ /lb MLVSS -day		0.28	0.28
Amount of nitrate that can be reduced	lb/day		4,550	6,400
Combined (aerated and anoxic zones)				
Total volume	MG	10.3		
Number of new basins	no	7		
Number of Phase III SSF basins	no	5		
Length to width ratio	ratio	7.6		
Depth, each	ft	17.0		
Width, each	ft	92.0		
Length, each	ft	126.0		
Volume, each	MG	1.48		
Detention time	hr		14.2	6.5
Detention time, with one basin out of service	hr		12.2	5.4

7.4 Secondary Clarification

Mixed liquor from the aeration basins will be conveyed to secondary clarifiers for sludge separation before filtration and disinfection. Some of the settled sludge will be recycled back to the aeration basins to maintain the desired MLSS concentration levels in the aeration basins. Suggested recycle ratios for MLE processes are from 50 to 100 percent of the influent flow. The design criteria presented in Table 7-5 are for recycle ratios between 50 and 60 percent. The amount of sludge wasted from the secondary clarifiers to the solids handling facilities will be approximately equal to the amount of sludge produced in the aeration basins to maintain the desired MCRT values.

Seven new 110-ft secondary clarifiers with water depths of 16 ft are proposed for the incremental plant expansion. The secondary clarifiers are sized based on recommended overflow rates and solids loading rates for nitrifying activated sludge systems. The overflow rates and solids loading rates in these clarifiers are presented in Table 7-6. Typical overflow rates for secondary clarifiers range from 400 to 700 gpd/ft² and from 1,000 to 1,600 gpd/ft² at average and peak flow, respectively [11]. As presented in Table 7-6 the overflow rates vary between approximately 260 and 650 gpd/ft² depending on the number of clarifiers in service and the flow regime. Typical solids loading rates for secondary clarifiers are from 1.0 to 1.5 lb/ft²·hr and less than 1.8 lb/ft²·hr at average and peak flow, respectively [11]. As presented in Table 7-6 the solids loading rates vary between 0.4 and 1.5 lb/ft²·hr depending on the number of clarifiers in service and loading conditions. Typical depths range from 12 to 20 feet. Deeper depths are recommended for improved performance and a larger margin of safety when upsets occur in the activated-sludge system.

**TABLE 7-6
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
DESIGN CRITERIA FOR INCREMENTAL PLANT EXPANSION
SECONDARY CLARIFICATION**

Parameter	Unit	Value	Average Conditions	Peak Conditions
Overflow rate	gpd/ft ²		260	575
Overflow rate, one clarifier out of service	gpd/ft ²		295	650
Number of new clarifiers	no	7		
Number of Phase III SSF clarifiers	no	2		
Diameter of each clarifier	ft	110		
Total area of new clarifiers	ft ²	66,652		
Water depth, ft	ft	16		
Solids loading rate	lb/hr-ft ²		0.4	1.4
Solids loading rate, with one clarifier out of service	lb/ft ² -hr		0.5	1.5

7.5 Return Activated Sludge/Waste Activated Sludge Handling

A return activated sludge (RAS) pumping station consisting of seven 15 to 20-hp RAS pumps (six duty and one standby) will provide RAS pumping (see Table 7-7). Each RAS pump is sized to provide a recycle flow up to 4.5 mgd at 15 ft total dynamic head (TDH). The total design RAS flow of approximately 27 mgd is equal to 70 percent of the peak design flow of 38.4 mgd. If necessary, the standby RAS pump is available to increase the total RAS flow rate to 31.5 mgd achieving a RAS ratio of approximately 80 percent at peak flow.

WAS will be conveyed to seven DAF units for thickening prior to anaerobic digestion. WAS will be directed to the DAF units from the discharge side of the RAS pumps. Under average conditions, the RAS pumps will provide sufficient pressure to convey WAS to the DAF units without supplemental pumping. However, under periods of increased wasting, booster pumps will be required to convey the WAS to the DAF units. Six one-hp inline booster pumps will be used for this purpose. A seventh booster pump will be in place for redundancy.

**TABLE 7-7
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
DESIGN CRITERIA FOR INCREMENTAL PLANT EXPANSION
RETURN ACTIVATED SLUDGE PUMPING**

Parameter	Unit	Average Conditions	Peak Conditions
Maximum design return ratio	percent	100	70
Maximum design return flow rate	mgd	17.5	26.9
Pump TDH	ft	15.0	15.0
Number of duty pumps	no	6.0	6.0
Pump efficiency	percent	70	70
Pump horsepower, each	hp	11.0	16.8

7.6 Effluent Filtration

Nine effluent filters are proposed for the incremental plant expansion (beyond Phase III) to remove the remaining total suspended solids in the secondary effluent. Filters will be cloth disk type, designed to comply with the turbidity requirements of the Title 22 wastewater reuse criteria. The daily average filtered effluent turbidity will be less than 2 nephelometric turbidity unit (NTU). Filter effluent turbidity objectives in accordance with the Title 22 requirements are summarized in Table 7-8. Filtration will also increase the downstream disinfection efficiency by removing the suspended solid particles that are disinfection obstacles.

TABLE 7-8
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
TERTIARY FILTRATION AND UV DISINFECTION OBJECTIVES
AS DEFINED IN TITLE 22 CRITERIA

Parameter	Value
Turbidity	24 hour average \leq 2 NTU 95 percent of values \leq 5 NTU At any time < 10 NTU
Total coliform bacteria	Running 7 day median \leq 2.2 MPN/100 mL No more than one event in 30 days \geq 23 MPN/100 mL At any time < 240 MPN/100 mL

The total filtration surface area for the incremental expansion is approximately 5,800 ft². As presented in Table 7-9 filtration rate varies between 2.1 and 4.9 gpm/ft² depending on the flow regime and number of filters in service. Typical maximum filtration rate for cloth type disk filters is between 5 and 6.5 gpm/ft². The backwash reject rate is anticipated to be between three and five percent.

TABLE 7-9
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
DESIGN CRITERIA FOR INCREMENTAL PLANT EXPANSION
FILTRATION

Parameter	Unit	Value	Average Conditions	Peak Conditions
Incremental filtration area required	ft ²	5,554		
Total number of Phase III units	no	6		
Total number of new units	no	9		
Number of filter disks per unit	no	12		
Diameter of individual filter disk	ft	6		
Filtration Rate	gpm/ft ²		2.1	4.6
Filtration rate during one filter out of service	gpm/ft ²		2.2	4.9
Backwash water reject ratio	percent		2 - 5	4 - 7

7.7 Rapid Mixing and Flocculation

Chemical addition prior to filtration may be necessary especially during high solids loading conditions to achieve the Title 22 turbidity requirements. Therefore, chemical addition facilities

are included to add coagulants and polymers prior to the filters. Two rapid mixing tanks and six flocculation tanks will be constructed to provide efficient mixing of chemicals and to form larger size flocs that are easily filterable. As seen in Table 7-10, the rapid mix tanks will be square in shape, 11 ft by 11 ft. The flocculation tanks will also be square in shape, 31.5 ft by 31.5 ft.

TABLE 7-10
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
DESIGN CRITERIA FOR INCREMENTAL PLANT EXPANSION
RAPID MIX AND FLOCCULATION

Parameter	Unit	Value	Average Conditions	Peak Conditions
Rapid Mix Tank				
Detention Time	sec		132	60
Number of new tanks	no	2		
Volume per tank	gal	13,400		
Sidewater depth	ft	15		
Required surface area per tank	ft ²	119		
Length	ft	11		
Width	ft	11		
Flocculation Tanks				
Detention Time	min		55	25
Number of new tanks	no	6		
Volume per tank	gal	111,100		
Sidewater depth	ft	15		
Required surface area per tank	ft ²	990		
Length	ft	31.5		
Width	ft	31.5		

7.8 UV Disinfection/Effluent Pumping

Filtered effluent must be disinfected to comply with the Title 22 wastewater reuse criteria for unrestricted reuse. Disinfected effluent coliform objectives in accordance with the Title 22 requirements are summarized in Table 7-10. For reasons of worker safety, environmental protection, and operational flexibility, an ultraviolet light disinfection system will be used. The installation will be a low-pressure high-intensity UV system. The pressure and intensity refer to the type of UV lamps used. Design criteria for the UV disinfection system are summarized in Table 7-11. Sizing of the UV system is based on guidelines published by NWRI as implemented by the California DHS. Four new UV channels (beyond Phase III) are proposed for the

incremental plant expansion. Similar to the initial UV disinfection/effluent pumping facility, the expanded system will also include effluent pumps to convey tertiary-treated wastewater through a new parallel 36-inch outfall.

**TABLE 7-11
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
DESIGN CRITERIA FOR INCREMENTAL PLANT EXPANSION
UV DISINFECTION**

Parameter	Unit	Value	Average Conditions	Peak Conditions
UV transmittance	%	55		
Minimum dose	uWs/cm ²	100,000		
Number of Phase III channels	no	2		
Number of new channels	no	4		
Banks, per channel	no	5		
Lamps, total	no	4,480		
Output, per lamp	W	150		
Power consumption	kW		593	1,300

7.9 Chemical Handling, Storage, and Metering

A chemical handling, storage, and metering facility will be required to support the tertiary filtration process as coagulant and polymer may be needed occasionally for filter aids. The equipment in the facility will include four bulk tanks and one day-tank for coagulant, metering pumps for the coagulant, space for four polymer tanks or totes, and a polymer dilution unit. Sizing of the metering pumps will accommodate peak dosing conditions. Suggested chemical doses are presented in Table 7-12. All tanks and metering pumps will be installed indoors, in a CMU building to prevent damage due to sunlight and temperature extremes.

**TABLE 7-12
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
SUGGESTED CHEMICAL DOSAGES FOR FILTER AIDS**

Chemical	Unit	Dosage	
		Typical	Maximum
Coagulant	mg/L	5-15	25
Polymer	mg/L	0.05-0.10	0.20

7.10 Dissolved Air Flotation (WAS Thickening)

Seven new DAF units are required for incremental plant expansion for WAS thickening. Sludge handling facilities are designed based on increased sludge production rates to provide flexibility for changes in the operational and process parameters. The observed heterotrophic yield coefficient of 0.28 was increased by approximately 50 percent for the design of the sludge handling facilities. Assuming a heterotrophic yield coefficient of 0.42, average and (daily) peak design WAS rates for the ultimate expansion facilities are anticipated to be approximately 19,800 lb/day and 65,000 lb/day, respectively. The design criteria for the DAF facilities are presented in Table 7-13. The DAF units are designed based on suggested maximum solid loading rate of 20 lb/ft²-day [11]. As presented in Table 7-13 solid loading rates vary between 6.2 and 23.9 lb/ft²-day depending on loading conditions and number of DAF units in service. At the higher loading rates, additional chemical usage may be required to achieve desired solids concentrations.

**TABLE 7-13
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
DESIGN CRITERIA FOR INCREMENTAL PLANT EXPANSION
DISSOLVED AIR FLOTATION (WAS THICKENING)**

Parameter	Unit	Value	Average Conditions	Peak Conditions
Daily peaking factor	ratio			3.29
WAS loading	lb/day		19,700	65,000
Loading rate	lb/ft ² -day		6.2	20.5
Loading rate with one unit out of service	lb/ft ² -day		7.3	23.9
Total new DAF area required	ft ²	3,162		
Number of new units	no	7		
Length to width ratio	ratio	3		
Area of one unit	ft ²	452		
Width of each unit	ft	12		
Length of each unit	ft	36		

7.11 Anaerobic Digestion and Cogeneration

As discussed previously, wastewater sludge generated in the primary sedimentation basins and activated sludge process will be anaerobically digested. New anaerobic digester facilities proposed as part of the incremental expansion include five digesters. New digesters will be 74 ft in diameter and 45 ft in height. The total minimum effective volume is 4.18 MG. Sizing of the new digesters is based upon solids loading and hydraulic detention time criteria. Recommended values for solids loading are between 0.1 and 0.3 lb VSS/ft³-d [9]. The average and peak (based

on 15 day peaking factor) CS loadings to the anaerobic digesters are approximately 45,000 lb/d and 83,000 lb/day, respectively. Based on historical data, approximately 83 percent of the solids are volatile. Therefore, the volatile solids loadings will be approximately 37,000 lb/day and 58,000 lb/day for average and peak conditions, respectively. As seen in Table 7-14, volatile suspended solids (VSS) loading will range from 0.08 to 0.13 lb VSS/ft³·d depending on the loading conditions. Typical values for hydraulic detention time are between 15 and 20 days [9]. Detention time will vary between 13 and 24 days depending on the loading conditions and the number of the digesters in service.

Anaerobic sludge digestion requires heating. The microorganisms responsible for the anaerobic digestion process operate most effectively at temperatures between 90 and 95°F. Sludge heating in the new digesters will occur in a similar fashion to the existing digesters. Sludge will be drawn off the digester mixing pipeline with a booster pump, conveyed through a spiral heat exchanger, and discharged back into the mixing pipeline.

**TABLE 7-14
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
DESIGN CRITERIA FOR INCREMENTAL PLANT EXPANSION
ANAEROBIC DIGESTION (SLUDGE DIGESTION)**

Parameter	Unit	Value	Average Conditions	Peak Conditions
15 day peaking Factor				1.56
CS loading	lb/day		44,900	83,100
Flow, gal/day	gpd		141,300	220,000
Volatile solids percentage	percent	82		
Dry volatile solids loading	lb/day		36,900	57,600
Number of new digesters	no	5		
Diameter of each digester	ft	74		
Effective minimum depth	ft	26		
Volume, total	MG	4.18		
Volume, each	MG	0.84		
Detention time (all digesters in service)	days		23.7	15.2
Detention time (with one digester out of service)	days		20.3	13.0
Volatile solids loading	lb VSS/day-ft ³		0.08	0.13
Volatile solids destruction, percent	percent		62	56

7.12 Dewatering Facilities

Anaerobically digested sludge will be dewatered in high solids centrifugal systems. Design criteria for the dewatering process are summarized in Table 7-15.

As a part of the Phase III improvements, a new centrifuge unit will be installed within a new dewatering building. The dewatering building will accommodate two 100-hp centrifuges at the completion of Phase III improvements with space for a new centrifuge unit for the incremental expansion. The centrifuges will be mounted on a platform within the building. To enhance the dewatering process, polymer will be injected into the sludge feed line.

Dewatered cake from the centrifuges will be discharged at a solids content of approximately 25 percent onto a solids handling conveyor. The conveyor will discharge cake outside the building onto a biosolids composting and storage area. As noted earlier, the centrifuges will be operated approximately 10 hr/day Monday through Friday for average conditions, and approximately 16 hr/day Monday through Saturday during peak sludge production. Considering these operational conditions, dewatered cake loading on the conveyor belt will vary between 8.6 and 8.9 tons/hour for the total plant flow (see Table 7-15). To store digester effluent generated during the weekends and non-working weekday hours, construction of an equalization tank is required. The size of the equalization tank is based on the need to store digested sludge from 5:00 p.m. on Friday to 8:00 a.m. on Monday or 63 hours. At the projected expansion CS flow rate of approximately 141,300 gal/day, the equalization tank requires a volume of 371,000 gal. An additional 15 percent storage volume is recommended as a factor of safety bringing the size of the equalization tank to 430,000 gal.

**TABLE 7-15
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
DESIGN CRITERIA FOR INCREMENTAL PLANT EXPANSION
CENTRIFUGE (SLUDGE DEWATERING)**

Parameter	Unit	Value	Average Conditions	Peak Conditions
Weekly peaking factor				1.82
Total number of Phase III units	no	2		
Number of new units	no	1		
Conveyor belt width	ft	2		
Hours of operation in a day	hr		10	16
Days of operation in a week	days		5	6
Centrifuge flow rate	gpm/unit		165	156
Centrifuge solids loading	lb/unit-hour		1,527	1,589
Dewatered solids content	Percent	25		
Belt solids loading (total plant)	tons/hr		2.1	2.2
Belt dewatered cake loading (total plant)	tons/hr		8.6	8.9

7.13 Phasing of Treatment Plant Improvements

To accommodate future increases in flow conveniently, two phases of construction are anticipated at the Manteca WQCF. Under Phase IV, the facility will be expanded to a treatment capacity of 17.5 mgd (ADWF), with Phase V representing buildout conditions (27 mgd ADWF). Site plans for Phase IV and Phase V are included as Figures 7-2 and 7-3, respectively. Two phases of construction are recommended also to minimize the impact on plant operations.

Figure 7-2 **Site Plan at Phase IV**

Figure 7-3 Site Plan at Phase V

8 Probable Construction Costs

This chapter summarizes the probable construction costs for the incremental expansion of the Manteca WQCF from approximately 10 mgd to 27 mgd. Unit costs are included in Appendix D. As presented in Table 8-1, treatment plant costs are projected at approximately \$99 million with a parallel 36-inch outfall anticipated cost of \$4.3 million (see Appendix E). Total incremental expansion costs are projected at approximately \$103 million.

**TABLE 8-1
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
PROBABLE CONSTRUCTION COSTS TO EXPAND FACILITY
FROM 10 MGD TO 27 MGD**

Unit Process	Probable Construction Costs
Influent Pump Station	1,985,000
Grit Removal/Primary Sedimentation	7,100,000
Aeration Basins	16,072,000
Secondary Clarification	8,357,000
Tertiary Filtration	5,829,000
UV Disinfection/Effluent Pumping	9,870,000
Equalization Pond	2,303,000
Chemical Building	1,291,000
Anaerobic Digestion / Sludge Heating	9,985,000
Thickening Facilities	2,840,000
Dewatering Facilities	1,119,000
Odor Control	1,659,000
Subtotal	68,410,000
Civil/Site Improvements	3,421,000
Yard Piping	6,841,000
Electrical	20,523,000
Subtotal, Treatment Facilities	99,195,000
Outfall, 36-inch	4,300,000
Grand Total	103,495,000

Expansion of the Manteca WQCF to build-out capacity is anticipated in two phases, Phase IV (17.5 mgd capacity) and Phase V (22 mgd capacity). A breakdown of probable construction costs by phase is included as Table 8-2.

TABLE 8-2
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN
PROBABLE CONSTRUCTION COSTS TO EXPAND FACILITY
FROM 10 MGD TO 27 MGD

COST BREAKDOWN BY PHASE

Unit Process	Probable Construction Costs		
	Total	Phase IV	Phase V
Influent Pump Station	1,985,000	1,985,000	--
Grit Removal/Primary Sedimentation	7,100,000	3,550,000	3,550,000
Aeration Basins	16,072,000	9,184,000	6,888,000
Secondary Clarification	8,357,000	4,775,000	3,582,000
Tertiary Filtration	5,829,000	2,915,000	2,914,000
UV Disinfection/Effluent Pumping	9,870,000	7,403,000	2,467,000
Equalization Pond	2,303,000	2,303,000	--
Chemical Building	1,291,000	1,291,000	--
Anaerobic Digestion / Sludge Heating	9,985,000	5,991,000	3,994,000
Thickening Facilities	2,840,000	1,623,000	1,217,000
Dewatering Facilities	1,119,000	1,119,000	--
Odor Control	1,659,000	1,659,000	--
Subtotal	68,410,000	43,798,000	24,612,000
Civil/Site Improvements (5%)	3,421,000	1,711,000	1,710,000
Yard Piping (10%)	6,841,000	4,789,000	2,052,000
Electrical (30%)	20,523,000	14,366,000	6,157,000
Subtotal, Treatment Facilities	99,195,000	64,664,000	34,531,000
Outfall, 36-inch	4,300,000	4,300,000	--
Grand Total	103,495,000	68,964,000	34,531,000

REFERENCES

- [1] *City of Manteca, Public Facilities Implementation Plan*, prepared by Nolte and Associates, December 1993.
- [2] California Regional Water Quality Control Board, Central Valley Region, *Waste Discharge Requirements for City of Manteca, City of Lathrop and Dutra Farms Wastewater Quality Control Facility, San Joaquin County*, March 2004.
- [3] California Regional Water Quality Control Board, Central Valley Region, *The Water Quality Control Plan (Basin Plan) – The Sacramento River Basin and the San Joaquin River Basin*, September 2004.
- [4] *City of Manteca General Plan 2023*, adopted October 6, 2003.
- [5] *Sewer Master Plan for City of Manteca Public Facilities Implementation Plan*, prepared by Nolte and Associates, December 1993.
- [6] *City of Manteca, Wastewater Collection System Master Plan Wastewater Generation Factor Technical Memorandum*, prepared by Nolte Associates, February 2004.
- [7] *Technical Memorandum 3-4, Evaluation of Rapid Infiltration on City-Owned Land Surrounding the Manteca Wastewater Quality Control Facility*, prepared by Nolte Associates, March 2002.
- [8] *Technical Memorandum No. 3-2, Evaluation of Urban Water Recycling Opportunities from the Manteca Wastewater Quality Control Facility*, prepared by Nolte Associates, February 2002.
- [9] Metcalf and Eddy, Inc., Wastewater Engineering: Treatment, Disposal, and Reuse, Third Edition, McGraw-Hill, 1991.
- [10] United States Environmental Protection Agency, Process Design Manual for Nitrogen Control, October 1975.
- [11] Water Environment Federation, Design of Municipal Wastewater Treatment Plants, Manual of Practice No. 8, 1992.

APPENDIX A
HOURLY FLOW RATES

Table A-1
Summary of WQCF Hourly Flows in 2003

	Maximum Hourly Flows				Peaking Factor			
	Average	Minimum	Maximum	Standard Deviation	Average	Minimum	Maximum	Standard Deviation
Winter ^a	11.54	7.50	12.50	1.25	1.98	1.29	2.15	0.21
Spring ^b	12.46	12.00	13.50	0.54	2.14	2.06	2.32	0.09
Summer ^c	12.32	8.00	14.00	1.45	2.12	1.38	2.41	0.25
Fall ^d	12.75	11.00	15.00	1.01	2.19	1.89	2.58	0.17

^a Based on WQCF flows between February 9, 2003 and February 22, 2003

^b Based on WQCF flows between May 11, 2003 and May 24, 2003

^c Based on WQCF flows between August 8, 2003 and August 24, 2003

^d Based on WQCF flows between November 9, 2003 and November 22, 2003

APPENDIX B
URBAN WATER RECYCLING OPPORTUNITIES

CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE

UPDATE OF URBAN WATER RECYCLING OPPORTUNITIES

TECHNICAL MEMORANDUM



SEPTEMBER 2004

NOLTE


BEYOND ENGINEERING

CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE

UPDATE OF URBAN WATER RECYCLING OPPORTUNITIES

TECHNICAL MEMORANDUM

SEPTEMBER 2004



Submitted to:

City of Manteca
Department of Public Works
1001 West Center Street
Manteca, CA 95337

Prepared by:

Nolte Associates, Inc.
302 Cherry Lane, Suite 201
Manteca, CA 95337
(209) 239-9080 • (209) 239-1166 (Fax)

CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE

UPDATE OF URBAN WATER RECYCLING OPPORTUNITIES

TECHNICAL MEMORANDUM

SEPTEMBER 2004

The purpose of this memorandum is to update urban water recycling opportunities within the City of Manteca (City). Potential urban reuse sites are identified and recycled water demands estimated. A conceptual distribution system is developed to serve these sites.

Background

The use of recycled water for unrestricted urban landscape irrigation represents an alternative for treated wastewater disposal. Effluent from the Manteca Wastewater Quality Control Facility (WQCF) is currently either land applied to approximately 360 acres of City owned/leased parcels or discharged to the San Joaquin River. The volume of effluent from the WQCF will increase as the City population increases. Discharges to existing land application sites are currently constrained. Due to the implementation of the California Toxics Rule and Total Maximum Daily Limits (TMDLs) for the San Joaquin River, continued river discharge may result in the need for expensive advanced treatment systems (e.g. ultrafiltration and reverse osmosis). Urban and agricultural land application of recycled water could augment the City's existing land application practices thus reducing reliance upon surface water discharges. The use of recycled water to meet landscaping demands would have the additional benefit of reducing demand on the City's potable water system. A review of agricultural land application sites was conducted recently in a separate technical memorandum [1]. This memorandum will review urban landscape irrigation sites.

Previous Reclamation Studies

Urban water recycling at the WQCF has been examined previously. The results of these previous studies are summarized below and provide a basis for this current examination of water recycling.

Manteca Effluent to Land Disposal Study, Technical Memorandum No. 3-2, Evaluation of Urban Water Recycling Opportunities from the Manteca Wastewater Quality Control Facility

Urban water recycling opportunities within the City were evaluated in 2002. The evaluation identified one hundred thirteen potential sites, ninety-four of which seemed economically feasible based on proximity to the WQCF and location near other sites. The total area of the ninety-four reuse sites was 935 acres, 711 acres of which were irrigable and could potentially

receive 3,200 ac-ft/yr of recycled water. The projected cost of construction for delivery facilities was \$10.1 million. With the inclusion of operation and maintenance costs, the cost for recycled water delivery was estimated at \$423/ac-ft.

1996 Phase III Pre-Design Water Reuse Investigation

An urban water reuse investigation was conducted at the WQCF in January 1996 [3]. In that investigation potential reuse sites were identified following a windshield survey of the community and a review of future development plans for areas south of State Route 120 (SR-120). The field survey focused upon parks, schoolyards, golf courses, and greenbelts that could be converted from potable water to recycled water for nonpotable demands. Sixty-three reuse sites with a total annual recycled water demand of approximately 2,700 ac-ft/yr were identified. Treatment and storage facilities were sized and costs were estimated to meet a maximum daily recycled water demand of 5.7 mgd. A conceptual recycled water distribution system was also sized and costs were estimated to meet peak hour demands. The investigation concluded that the life cycle cost of supplying recycled water would be approximately \$470/ac-ft.


The 1996 investigation also evaluated the projected recycled water quality from the Manteca WQCF in terms of its suitability for irrigation. Considering multiple water quality parameters, it was concluded that the recycled water would be suitable for landscape irrigation without restrictions.

Current Recycled Water Demands

For this memorandum, water reuse sites have been identified using the General Plan [4] land use diagram and by conducting a windshield survey. Parcels zoned for parks, schools, churches and open space within the City were identified. Additionally, sites identified in previous water recycling evaluations were re-visited and the area along Tidewater Bikeway and Caltrans right-of-ways along SR-120 were included. In total, one hundred sixty possible water recycling sites were located (see Figure 1). However, to be economically feasible, reuse sites should be either close to the WQCF and/or clustered near other sites. Therefore, from the one hundred sixty potential sites, twenty-six sites were eliminated from further consideration on the basis of being either too far or too isolated from other locations. The sites eliminated from consideration were principally located to the east of State Route 99 (SR-99). The remaining one hundred thirty-four reuse sites represent a total area of 1,285 acres, of which 817 acres are assumed to be irrigable. Caltrans right-of-ways along SR-120 accounts for approximately 65 acres and the Tidewater Bikeway accounts for approximately 26 acres. Most of the future water recycling demands are located south of SR-120. The irrigable area for each site was estimated based on the following assumptions:

1. Parks - 90 percent of area is irrigable
2. Schools - 50 percent of area is irrigable
3. Churches - 50 percent of area is irrigable
4. Open Space - 50 percent of area is irrigable

The gross area and projected irrigable area for each reuse site are presented in Table 1.



LEGEND

- P (PARK)
- PQP (PUBLIC/QUASI-PUBLIC)
- OS (OPEN SPACE)
- UR-P
- TIDEWATER BIKEWAY
- CALTRANS RIGHT-OF-WAY
- WASTEWATER QUALITY CONTROL FACILITY
- 23 REUSE SITE NUMBER 23. REFER TO TABLE 1 FOR ADDITIONAL INFORMATION

- NOTES:
1. PARCELS WITHOUT A NUMBER ARE NOT RECOMMENDED FOR REUSE SITES DUE TO LOCATION AND/OR SIZE

FIGURE 1
CITY OF MANTECA WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN UPDATE
UPDATE OF URBAN WATER RECYCLING OPPORTUNITIES
LOCATION OF POTENTIAL WATER REUSE SITES
NOLTE BEYOND ENGINEERING

TABLE I
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE
UPDATE OF URBAN WATER RECYCLING OPPORTUNITIES
SUMMARY OF RECYCLED WATER DEMANDS AT GENERAL PLAN BUILD-OUT

Reuse Site No.	Land Use Designation	Description	Total Area, acres	Irrigable area ^a , acres	Reclamation Demands		
					Applied Water ^b , ac-ft/yr	Max. day demand ^d	Peak hour delivery ^e
1	Park	Manteca Park Golf Course	75.59	67.85	305.3	0.655	455
2	Public/Quasi-Public	East Union School	57.08	28.54	128.4	0.276	574
3	Park	Manteca Park Golf Course	44.20	39.78	179.0	0.384	267
4	Park	Woodward Community Park	33.43	30.09	135.4	0.291	605
5	Park	Woodward Community Park	17.20	15.48	69.7	0.150	311
6 ^a							
7	Public/Quasi-Public	George McParland School	15.31	7.66	34.4	0.074	154
8	Public/Quasi-Public	Neil Hafley School	14.12	7.06	31.8	0.068	142
9	Park	Chadwick Square	9.00	8.10	36.5	0.078	163
10							
11	Park	Northgate Park	5.45	4.91	22.1	0.047	99
12	Park	Villa Ticino Park	5.59	5.03	22.6	0.049	101
13	Park	Bella Vista Park	5.02	4.52	20.3	0.044	91
14	Park	Yosemite Village Park	4.89	4.40	19.8	0.043	89
15	Park	Doxey Park	4.45	4.01	18.0	0.039	81
16	Park	Curran Grove	4.42	3.98	17.9	0.038	80
17	Park	Park West	4.34	3.91	17.6	0.038	79
18	Park	Mayor's Park	3.99	3.59	16.2	0.035	72
19	Park	Greystone Park	4.00	3.60	16.2	0.035	72
20	Park	Bay Meadows Park	4.00	3.60	16.2	0.035	72
21	Park	Doxey Park	3.99	3.59	16.2	0.035	72
22	Park	Sequoia Park	3.98	3.58	16.1	0.035	72
23	Park	Crestwood Park	3.85	3.47	15.6	0.033	70
24	Park	Cotta Park	3.71	3.34	15.0	0.032	67
25	Park	Union West Park	3.69	3.32	14.9	0.032	67
26							
27							
28	Park	Lincoln Park	3.67	3.30	14.9	0.032	66
29	Park	Southside Park	3.31	2.98	13.4	0.029	60
30	Park	Roberts Park	3.29	2.96	13.3	0.029	60
31	Park	Colony Park	3.26	2.93	13.2	0.028	59
32	Park	Park West	3.12	2.81	12.6	0.027	56
33	Park	Franciscan Park	2.61	2.35	10.6	0.023	47
34	Park	Quail Ridge Park	3.05	2.75	12.4	0.027	55
35							
36							
37	Public/Quasi-Public	Church of Jesus Christ of Latter Day Saints	2.66	1.33	6.0	0.013	27
38	Park	Park West	2.36	2.12	9.6	0.021	43
39	Park	St. Francis Park	2.14	1.93	8.7	0.019	39
40	Park	Walnut Place Park	2.02	1.82	8.2	0.018	37
41	Park	Park West	1.80	1.62	7.3	0.016	33
42	Park	St. Francis Park	1.78	1.60	7.2	0.015	32
43	Park	Colony Park	1.76	1.58	7.1	0.015	32
44	Park	Roberts Park	1.78	1.60	7.2	0.015	32
45	Park	Park West	1.69	1.52	6.8	0.015	31
46	Park	William Martin Park	1.56	1.40	6.3	0.014	28
47	Park	Library Park	1.47	1.32	6.0	0.013	27
48	Park	Park West	1.40	1.26	5.7	0.012	25
49	Park	Park West	1.38	1.24	5.6	0.012	25
50	Park	Baccieri Park	1.27	1.14	5.1	0.011	23
51							
52	Park	Greystone Park	1.20	1.08	4.9	0.010	22
53	Park	Franciscan Park	0.95	0.86	3.8	0.008	17
54	Park	St. Francis Park	0.85	0.77	3.4	0.007	15
55							
56							
57							
58	Park	Wilson Park	0.38	0.34	1.5	0.003	7
59	Park	Hilderband Park	0.29	0.26	1.2	0.003	5
60	Park	Hilderband Park	0.29	0.26	1.2	0.003	5

TABLE 1
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE
UPDATE OF URBAN WATER RECYCLING OPPORTUNITIES
SUMMARY OF RECYCLED WATER DEMANDS AT GENERAL PLAN BUILD-OUT

Reuse Site No.	Land Use Designation	Description	Total Area, acres	Irrigable area ^a , acres	Reclamation Demands		
					Applied Water ^b , ac-ft/yr	Max. day demand ^d	Peak hour delivery ^e
61	Park	Park West	0.18	0.16	0.7	0.002	3
62	Park	Yosemite Village Park	0.10	0.09	0.4	0.001	2
63							
64							
65	Public/Quasi-Public	Stella Brockman School	19.52	9.76	43.9	0.094	196
66	Public/Quasi-Public	Senior Center	9.52	4.76	21.4	0.046	96
67							
68	Public/Quasi-Public	Brock Elliott School	18.43	9.22	41.5	0.089	185
69	Public/Quasi-Public	Golden West School	13.41	6.71	30.2	0.065	135
70							
71	Public/Quasi-Public	Lincoln Elementary School	9.95	4.98	22.4	0.048	100
72	Public/Quasi-Public	Manteca Adult School	4.14	2.07	9.3	0.020	42
73							
74	Public/Quasi-Public	Manteca High School	13.64	6.82	30.7	0.066	137
75							
76							
77							
78							
79	Public/Quasi-Public	St. Anthony's Catholic Church	3.06	1.53	6.9	0.015	31
80	Public/Quasi-Public	Sequoia High	5.33	2.67	12.0	0.026	54
81							
82	Public/Quasi-Public	Sierra High School	46.22	23.11	104.0	0.223	465
83	Public/Quasi-Public	Union Cemetary	4.40	2.20	9.9	0.021	44
84	Public/Quasi-Public	Sequoia Annex School	3.78	1.89	8.5	0.018	38
85	Public/Quasi-Public	1st Baptist Church	2.46	1.23	5.5	0.012	25
86	Public/Quasi-Public	St. Paul's United Methodist Church	2.45	1.23	5.5	0.012	25
87	Public/Quasi-Public	St. Paul's United Methodist Church	0.43	0.22	1.0	0.002	4
88	Public/Quasi-Public	Fellowship Baptist Church of Manteca	1.38	0.69	3.1	0.007	14
89	Public/Quasi-Public	Freedom Christian Center	2.55	1.28	5.7	0.012	26
90							
91	Public/Quasi-Public	1st Christian Church	3.81	1.91	8.6	0.018	38
92	Public/Quasi-Public	Manteca Fire Station	1.32	0.66	3.0	0.006	13
93	Public/Quasi-Public	Sequoia Heights Baptist Church	0.74	0.37	1.7	0.004	7
94	Public/Quasi-Public	Sequoia Heights Baptist Church	0.24	0.12	0.5	0.001	2
95	Public/Quasi-Public	Sequoia Heights Baptist Church	1.23	0.62	2.8	0.006	12
96	Public/Quasi-Public	Doctors Hospital of Manteca	0.95	0.48	2.1	0.005	10
97	Public/Quasi-Public	Doctors Hospital of Manteca	2.92	1.46	6.6	0.014	29
98	Public/Quasi-Public	(Northgate Community) Church	2.37	1.19	5.3	0.011	24
99	Public/Quasi-Public	Manteca Adventist School	3.02	1.51	6.8	0.015	30
100	Public/Quasi-Public	Manteca High	4.43	2.22	10.0	0.021	45
101	Public/Quasi-Public	Lincoln Elementary School	3.43	1.72	7.7	0.017	35
102							
103	Public/Quasi-Public	Sequoia High	8.96	4.48	20.2	0.043	90
104							
105							
106	Public/Quasi-Public	United Lutheran Church	3.84	1.92	8.6	0.019	39
107	Public/Quasi-Public	Calvary Community Church	23.98	11.99	54.0	0.116	241
108	Public/Quasi-Public	Manteca High	15.35	7.68	34.5	0.074	154
109							
110							
111	Open Space		204.43	102.22	460.0	0.987	2057
112	Open Space		35.27	17.64	74.0	0.151	158
113	Open Space		71.37	35.69	160.6	0.345	318
114	Open Space		9.23	4.62	20.8	0.045	93
115	Open Space		14.29	7.15	32.2	0.069	144
116	Open Space		1.05	0.53	2.4	0.005	11
117	Open Space		21.84	10.92	49.1	0.105	220
118	Park	Primavera Park	6.98	3.49	16.5	0.034	126
119	Public/Quasi-Public	George McParlana Annex School	4.17	2.09	9.4	0.020	42
120	Park	Gonsalves Park	2.17	1.09	4.8	0.019	39

TABLE 1
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE
UPDATE OF URBAN WATER RECYCLING OPPORTUNITIES
SUMMARY OF RECYCLED WATER DEMANDS AT GENERAL PLAN BUILD-OUT

Reuse Site No.	Land Use Designation	Description	Total Area, acres	Irrigable area ^b , acres	Reclamation Demands		
					Applied Water ^c , ac-ft/yr	Max. day demand ^d	Peak hour delivery ^e
121	Park	Gonsalves Estates Park	1.13	1.02	4.6	0.010	20
122	Park	Dutra Farms S.E. Park	6.95	6.26	28.1	0.060	126
123	Park		10.49	9.44	42.5	0.091	190
124	Park		5.67	5.10	23.0	0.049	103
125	Park		4.72	4.25	19.1	0.041	85
126	Park		5.73	5.16	23.2	0.050	104
127	Park		9.21	8.29	37.3	0.080	167
128	Park		8.69	7.82	35.2	0.076	157
129	Public/Quasi-Public	Future School	17.65	8.83	39.7	0.085	178
130	Park		10.25	9.23	41.5	0.089	186
131	Park		8.46	7.61	34.3	0.074	153
132	Park		13.65	12.29	55.3	0.119	247
133	Park		8.27	7.44	33.5	0.072	150
134	Park		9.03	8.13	36.6	0.078	164
135	Park		7.16	6.44	29.0	0.062	130
136	Park		9.06	8.15	36.7	0.079	164
137	Park		6.86	6.17	27.8	0.060	124
138	Park		5.32	4.79	21.5	0.046	96
139	Park		3.98	3.58	16.1	0.035	72
140	Open Space	CalTrans Right-of-Way	6.00	3.00	13.5	0.029	60
141	Open Space	CalTrans Right-of-Way	6.00	3.00	13.5	0.029	60
142	Open Space	CalTrans Right-of-Way	3.95	1.98	8.9	0.019	40
143	Open Space	CalTrans Right-of-Way	3.95	1.98	8.9	0.019	40
144	Open Space	CalTrans Right-of-Way	1.12	0.56	2.5	0.005	11
145	Open Space	CalTrans Right-of-Way	4.96	2.48	11.2	0.024	50
146	Open Space	CalTrans Right-of-Way	6.75	3.37	15.2	0.033	68
147	Open Space	CalTrans Right-of-Way	6.00	3.00	13.5	0.029	60
148	Open Space	CalTrans Right-of-Way	6.00	3.00	13.5	0.029	60
149	Open Space	CalTrans Right-of-Way	3.95	1.98	8.9	0.019	40
150	Open Space	CalTrans Right-of-Way	3.95	1.98	8.9	0.019	40
151	Open Space	CalTrans Right-of-Way	1.12	0.56	2.5	0.005	11
152	Open Space	CalTrans Right-of-Way	4.96	2.48	11.2	0.024	50
153	Open Space	CalTrans Right-of-Way	6.75	3.37	15.2	0.033	68
154	Open Space	Tidewater Biketrail	5.98	2.99	13.4	0.029	60
155	Open Space	Tidewater Biketrail	5.84	2.92	13.1	0.028	59
156	Open Space	Tidewater Biketrail	5.86	2.93	13.2	0.028	59
157	Open Space	Tidewater Biketrail	4.12	2.06	9.3	0.020	41
158	Open Space	Tidewater Biketrail	0.98	0.49	2.2	0.005	10
159	Open Space	Tidewater Biketrail	1.87	0.94	4.2	0.009	19
160	Open Space	Tidewater Biketrail	1.54	0.77	3.5	0.007	15
Total			1284.7	817.3	3677.8	7.9	15000.1

^aNon-designated land use sites are not recommended for recycled water service due to location and/or size

^b90% of total area for parks and golf course and 50% of total area for schools, churches, hospitals, cemetery, fire station, senior center and open space

^cBased on a 4.5-inch per year application rate

^dBased on a 0.355 inches per day maximum daily demand (in July)

^eAssuming an 8-hour irrigation period, except for the 24-hour irrigation period for the Manteca Golf Course

Table 1 also identifies the annual, maximum daily, and peak hourly recycled water demand for each site. The total recycled water demand for the one hundred thirty-four reuse sites at General Plan build-out is approximately 3,700 ac-ft/yr (recycled water demand for existing land uses is 1,750 ac-ft/yr). During July, the reuse sites are projected to require a daily recycled water delivery of 7.9 mgd. The peak hour delivery would be approximately 15,000 gpm.

The water applied to each site was estimated by multiplying the site's irrigated acreage by the depth of water required. The annual demand, as indicated in Table 2, was estimated to be approximately 54-in/yr. The maximum daily demand of 0.35-in/day was estimated based on the highest monthly (July) irrigation requirement of 11.0-in/month divided by 31 days. The peak hourly demand, used to size the recycled water distribution system, was based on an irrigation cycle for parks, schools, and the cemetery from 10 p. m. to 6 a. m., a period of eight hours per day. This restricted irrigation window reduces the potential for public contact with recycled water. The golf course was assumed to receive water twenty-four hours per day. The delivery time for these potential customers is longer because it is assumed that ponds for temporary storage of irrigation water would be used at these sites. The peak delivery requirement occurs during the eight-hour period used for irrigation by all customers.

TABLE 2
CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE
UPDATE OF URBAN WATER RECYCLING OPPORTUNITIES
LANDSCAPE IRRIGATION WATER BALANCE

Month	ET ^a Evapotranspiration, in	P ₁₀ ^b Precipitation, in	CD ^c Crop Demand, in	LR ^d Leaching Req't, in	AW ^e Applied Water, in
Jan	0.92	3.12	-	-	-
Feb	1.49	2.70	-	-	-
Mar	3.05	2.42	0.63	0.06	0.9
Apr	4.72	1.35	3.37	0.34	4.6
May	6.35	0.52	5.83	0.58	8.0
Jun	7.68	0.11	7.57	0.76	10.4
Jul	8.06	0.08	7.98	0.80	11.0
Aug	6.83	0.07	6.76	0.68	9.3
Sep	5.31	0.25	5.06	0.51	7.0
Oct	3.30	0.91	2.39	0.24	3.3
Nov	1.42	2.07	-	-	-
Dec	0.61	2.88	-	-	-
Total	49.74	16.48	39.59	3.96	54.4

^a ET_o: Evapotranspiration rates computed from Figure 5-11, *Irrigation with Reclaimed Municipal Wastewater* [5].

^b P₁₀: One in ten year precipitation values from *California Rainfall Summary*, Manteca gage station [6].

^c CD: Crop Demand = (ET - P₁₀) positive values.

^d LR: Leaching Requirement = 0.10*(CD).

^e AW: Applied Water = (CD+LR)/0.80.

Recycled Water System Facilities

In this section, recycled water storage, pumping, and distribution system facilities are described.

Storage System


At General Plan build-out, the average dry weather flow to the WQCF is 27 mgd which is greater than the projected recycled water delivery requirement of 15,000 gpm. The daily recycled water demand schedule will require some operational storage, however. Typical operational storage requirements are approximately one-half of the maximum daily demand or 4.0 MG (50 percent of 7.9 mgd).

Delivery (Pumping and Conveyance)

A recycled water pump station has been sized to meet peak delivery schedules with the largest pump removed from service. A delivery pressure of 60 psi is assumed for landscape irrigation customers except where onsite storage ponds are available such as at the golf course. Pipe sizes for the recycled water distribution system were selected based on a criterion of headloss no greater than 8 feet per 1,000 feet, using a Hazen-Williams coefficient of 120. Peak hour deliveries to each potential irrigation site were used to size the pipelines. The layout of the distribution system is presented in Figure 2.

It can be seen in Figure 2 that the recycled water distribution system consists of a large loop encircling the majority of the City with one branch line to the north and a second branch line to the south. The recycled water pipeline has been routed to provide access to the majority of the reuse sites. Use of a looped system improves pressure distribution and provides redundancy in the event of a pipe failure. The existing 12-inch Stage II force main on Woodward Road could be converted to a 12-inch recycled water pipeline if the timing is appropriate.

The head losses associated with flow through each pipe were used to determine the overall system head loss and pumping requirement. The greatest headloss (45 psi) occurs along the route from the WQCF to the eastern sites on Woodward Road. Assuming a minimum endpoint delivery pressure of 60 psi, the initial pressure at the WQCF is approximately 105 psi. To maintain a pumping pressure of 105 psi at 15,000 gpm requires approximately 654 horsepower (assuming pump efficiency of 75 percent). Proposed design criteria for the recycled water delivery system are presented in Table 3.



LEGEND

- PROPOSED PIPELINE
- 24" PROPOSED PIPE SIZE
- WASTEWATER QUALITY CONTROL FACILITY

FIGURE 2

CITY OF MANTECA
WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE

UPDATE OF URBAN WATER
RECYCLING OPPORTUNITIES

**PROPOSED RECYCLED WATER
DISTRIBUTION PIPELINES**

NOLTE
BEYOND ENGINEERING

TABLE 3
 CITY OF MANTECA
 WASTEWATER QUALITY CONTROL FACILITY
 MASTER PLAN UPDATE
 UPDATE OF URBAN WATER RECYCLING OPPORTUNITIES
 DESIGN CRITERIA FOR RECYCLED WATER DELIVERY SYSTEM

Item	Units	Value
<u>Recycled Water Pump Station</u>		
Peak delivery flow	gpm	15,000
Maximum operating head	psi	105
Total connected horsepower at build-out	hp	654
<u>Recycled Water Distribution Pipe System</u>		
Discharge pressure	psi	60
Pipe material	type	plastic
Headloss	ft/1000 ft	8
Hazen-Williams coefficient	C	120
Maximum velocity (at peak flow)	ft/s	5
Minimum velocity (at peak flow)	ft/s	3
30-in pipe	ft	8,200
24-in pipe	ft	19,200
20-in pipe	ft	12,000
18-in pipe	ft	6,200
16-in pipe	ft	11,200
12-in pipe	ft	12,200
Total Length of pipe	ft	69,000

Summary

Based on the General Plan build-out land use, one hundred thirty-four sites within the City comprising 817 acres, have been identified as candidates for receiving recycled water. These sites could potentially use 3,700 ac-ft/yr of recycled water, which represents 33 percent of the annual Phase III wastewater flow of 11,230 ac-ft/yr (10 mgd). Treatment, storage, and distribution facilities would be necessary to meet this demand.

REFERENCES

- [1] *Evaluation of Agricultural Irrigation with Recycled Water*, prepared by Nolte Associates, July 2004.
- [2] *Manteca Effluent to Land Disposal Study, Technical Memorandum No. 3-2, Evaluation of Urban Water Recycling Opportunities from the Manteca Wastewater Control Facility*, prepared by Nolte Associates, February 2002.

- [3] *Water Reuse Investigation Preliminary Design Report, TM No.4 - Manteca Wastewater Quality Control Facility (WQCF) Phase III Expansion*, prepared by Nolte and Associates, January 1996.
- [4] City of Manteca General Plan 2023 Policy Document, adopted October 6, 2003.
- [5] *Irrigation with Reclaimed Municipal Wastewater - A Guidance Manual*, prepared by the California State Water Resources Control Board, July 1984.
- [6] California Rainfall Summary, prepared by the California Department of Water Resources, 1981.

APPENDIX C
ROUTE STUDY FOR PARALLEL SEWER

On August 2nd, 2006 Nolte staff walked the existing outfall route between the WQCF and the discharge point at the San Joaquin River to identify potential constraints and pipeline route alignment opportunities for the design and construction of a future outfall. Existing utility maps and other information were collected from the City of Manteca and the San Joaquin County Surveyor. The alignment walk-through was divided into the following reaches: 1) beginning at the WQCF west towards McKinley Avenue; 2) from McKinley Avenue south to State Route 120 (SR-120); 3) from the SR-120 corridor between McKinley Avenue and the Union Pacific Railroad (UPRR); 4) UPRR corridor between SR-120 and the San Joaquin River. A brief summary of the potential constraints identified for each reach and a suggested alignment are provided below. A key map for the overall existing outfall is presented in Figure C-1.

a. Reach 1 – WQCF to McKinley Avenue

The walk-through began at the WQCF between the Secondary Effluent Storage Pond (SESP) and the Chemical Handling Building area. This reach ended at McKinley Avenue. Reach 1 is located on City property. Above ground utilities included overhead electrical transmission lines along the western portion of the reach. A significant number of buried pipelines are located between the SESP and Chemical Handling Building. The existing 36-inch pipeline runs underneath plant service roads and adjacent to pond berms. The existing outfall is approximately 3 feet below grade. Signs are located at several locations along the route. The existing outfall crosses a small irrigation ditch for approximately 30 feet before reaching McKinley Avenue. Site observations indicate that sufficient space is available throughout most of this reach for a future 36-inch outfall to be routed parallel to the existing outfall. A schematic representation of the existing utilities and constraints along Reach 1 is presented in Figure C-2.

b. Reach 2 – McKinley Avenue to SR-120

Reach 2 begins at the intersection of the WQCF property and is located along McKinley Avenue and ends south of SR-120. The existing outfall is located on the west side of McKinley Avenue, approximately ten feet from the road centerline with approximately 48 inches of cover. Existing utilities include overhead electrical and telephone lines on the east side of McKinley Avenue. Signage for a buried GTE cable was located on McKinley Avenue south of SR-120 where the pipeline turns west. The existing outfall is centered within a 20 foot permanent easement located within McKinley Avenue. The future outfall could be located east of the existing alignment, within the permanent easement. An additional 10 feet of temporary construction easement within private properties and Caltrans right-of-way (ROW) is recommend for this area. A schematic representation of the existing utilities and constraints along Reach 2 is presented in Figure C-3.

c. Reach 3 – SR-120 between McKinley Avenue and UPRR

Reach 3 parallels SR-120 from McKinley Avenue to the UPRR. The existing outfall is located along the northern perimeter of several private properties, and is outside of the Caltrans ROW for SR-120. The outfall is centered within a 20-foot permanent easement. No existing utilities were identified in the area. The future outfall could be located north or south of the existing

alignment, within the permanent easement. An additional 10 feet of temporary construction easement is recommended for this area. A schematic representation of the existing utilities and constraints along Reach 3 is presented in Figure C-4.

d. Reach 4 –UPRR between SR-120 and San Joaquin River

Reach 4 parallels the UPRR from SR-120 to the San Joaquin River. Reach 4 is routed through the Oakwood Shores gated community, currently under construction. Site observations and a review of improvement plans for the community indicate that a 70 to 75 foot landscaped private access easement has been provided along the existing outfall alignment. Existing utilities in the area include overhead electrical lines, a 12-inch buried water line, and buried recycled water lines. Electrical vaults for landscaping, radio towers foundations, and a refueling tank with generator were also observed near the alignment. The outfall is located within a 20-foot permanent easement. The outfall is centered within this easement for a portion of the alignment. For the remainder of the alignment, the outfall is located five-feet from the southerly limit of the easement, to avoid an existing 12-inch water line.

The future outfall could be located south of the existing alignment. For sections of the alignment where the existing outfall is not centered within the permanent easement, an additional 10 feet of permanent easement may be required. A 10 foot temporary construction easement is recommended along the entire reach. The future outfall would probably be installed using trenchless methods when crossing below the east levee along the San Joaquin River. Therefore a 15 foot temporary construction easement is recommended for this area. Potential constraints for design and construction of the future outfall along this reach include avoiding mature oak trees near the river, access to the San Joaquin River, and access within the gated community. A schematic representation of the existing utilities and constraints along Reach 4 is presented in Figure C-5.





FIGURE C-1
 MANTECA WASTEWATER QUALITY CONTROL FACILITY
 MASTER PLAN UPDATE

**EXISTING AND PROPOSED OUTFALL ROUTE
 KEY MAP**

NOLTE
 BEYOND ENGINEERING



REACH 1— WQCF TO MCKINLEY AVENUE
SCHEMATIC PLAN
 NOT TO SCALE

LEGEND

- FUTURE OUTFALL PIPELINE
- EXISTING OUTFALL PIPELINE
- OVERHEAD ELECTRICAL AND TRANSMISSION LINES
- ~~~~~ IRRIGATION DITCH



WQCF—FACING WEST
 BETWEEN SECONDARY EFFLUENT
 STORAGE POND AND CHEMICAL BUILDING



WQCF—FACING SOUTH
 WESTERN LEVEE OF ECKERT POND



WQCF—FACING SOUTHWEST
 SOUTH END OF ECKERT POND
 NEAR APPLICATION FIELDS




WQCF—FACING WEST
 AT IRRIGATION DITCH CROSSING

FIGURE C-2
 MANTECA WASTEWATER QUALITY CONTROL FACILITY
 MASTER PLAN UPDATE

REACH 1
WQCF TO MCKINLEY AVENUE





REACH 2—MCKINLEY AVENUE TO SR—120

SCHEMATIC PLAN

NOT TO SCALE

LEGEND

- FUTURE OUTFALL PIPELINE
- EXISTING OUTFALL PIPELINE
- OVERHEAD ELECTRICAL AND TRANSMISSION LINES
- IRRIGATION DITCH



MCKINLEY AVENUE—FACING SOUTH
OVERHEAD UTILITIES ON EAST SIDE OF ROAD



MCKINLEY AVENUE—FACING WEST
BETWEEN BRONZAN ROAD AND SR-120




MCKINLEY AVENUE—FACING EAST
BURIED UTILITY CABLE SIGN FOR GTE

FIGURE C-3
MANTECA WASTEWATER QUALITY CONTROL FACILITY MASTER PLAN UPDATE
REACH 2 MCKINLEY AVENUE TO SR-120
NOLTE BEYOND ENGINEERING



SERVICE ROAD FACING NORTH TO SR-120 AND UPRR INTERSECTION




REACH 3- SR-120 BETWEEN MCKINLEY AVENUE AND UPRR
SCHEMATIC PLAN
 NOT TO SCALE

LEGEND

- FUTURE OUTFALL PIPELINE
- _____ EXISTING OUTFALL PIPELINE
- _____ OVERHEAD ELECTRICAL AND TRANSMISSION LINES



SERVICE ROAD FACING EAST TOWARD MCKINLEY AVENUE
 BENCHMARKS BY ASSOCIATED ENGINEERING GROUP



SERVICE ROAD FACING WEST TOWARD MCKINLEY AVENUE
 BLOW OFF VALVE ON EXISTING OUTFALL



SERVICE ROAD FACING EAST TO MCKINLEY AVENUE
 OVERHEAD UTILITIES NORTH OF SERVICE ROAD

FIGURE C-4

CITY OF MANTECA WASTEWATER QUALITY CONTROL FACILITY
 MASTER PLAN UPDATE


REACH 3
SR-120 BETWEEN MCKINLEY AVENUE
AND UPRR

NOLTE
 BEYOND ENGINEERING



PHOTO 12

SERVICE ROAD FACING WEST TOWARD SAN JOAQUIN RIVER
OVERHEAD UTILITIES NORTH OF SERVICE ROAD
RECYCLED WATER LINE SPRINKLER CONNECTIONS
SOUTH OF SERVICE ROAD



REACH 4- UPRR TO SAN JOAQUIN RIVER
SCHEMATIC PLAN
NOT TO SCALE



PHOTO 13

FACING SOUTH FROM SERVICE ROAD
RECLAIMED WATER SPRINKLER SYSTEM
APPROXIMATELY 30 FEET FROM OUTFALL PIPELINE



PHOTO 14

FACING WEST FROM SERVICE ROAD
FUEL TANK AND GENERATOR



PHOTO 15

SERVICE ROAD FACING SOUTHWEST
TO SAN JOAQUIN RIVER
NUMEROUS OAK TREES AROUND AREA




PHOTO 16

OUTFALL FACING SOUTHWEST FROM LEVEE
SAN JOAQUIN RIVER OUTFALL




PHOTO 17

END OF OUTFALL FACING EAST

FIGURE C-5

CITY OF MANTECA WASTEWATER QUALITY CONTROL FACILITY
MASTER PLAN UPDATE

REACH 4
UPRR TO SAN JOAQUIN RIVER



APPENDIX D
UNIT COST INFORMATION FOR OPINION OF
PROBABLE CONSTRUCTION COSTS

**Table D-1
Unit Costs for Treatment Plant Expansion**

Unit Process	Unit	Unit Cost	Probable Construction Cost, \$
Influent Pump Station	MGD	120,000	1,985,000
Grit Removal/Primary Sedimentation	sq ft - primary Clarifier	300	7,100,000
Aeration Basins	MG	1,560,400	16,072,000
Secondary Clarification	ft - diameter	10,900	8,357,000
Tertiary Filtration	sq ft	900	5,829,000
UV Disinfection/Effluent Pumping	UV Lamp	2,490	9,870,000
Equalization Pond	MGD	134,000	2,303,000
Chemical Building	sq ft	620	1,291,000
Anaerobic Digestion/Sludge Heating	ft - diameter	27,000	9,985,000
Thickening Facilities	MGD	166,000	2,840,000
Dewatering Facilities	MGD	65,000	1,119,000
Odor Control	MGD	100,000	1,659,000
Subtotal			68,410,000
Civil/Site Improvements	Percent of Total	5%	3,421,000
Yard Piping	Percent of Total	10%	6,841,000
Electrical	Percent of Total	30%	20,523,000
Subtotal			99,195,000
Outfall	Linear ft	298.6	4,300,000
Grand Total			103,495,000

APPENDIX E
PROBABLE CONSTRUCTION COSTS FOR
PARALLEL LAND OUTFALL

Table E-1
Preliminary Opinion of Probable Construction Costs for Parallel Land Outfall

Unit Process	Unit	Estimated Quantity	Unit Cost	Probable Construction Cost, \$
Mobilization	LS	1	60,000	60,000
36" Concrete Outfall Pipeline	LF	14,400	276	3,974,400
Bore and Jack at San Joaquin River – Pipe and Installation	LF	200	480	96,000
Bore and Jack Receiving Pit	EA	2	30,000	60,000
Bore and Jack Pit Dewatering / Cofferdam	EA	2	6,000	12,000
Blow-off Valve	EA	2	600	1,200
Air Release Valve	EA	3	12,000	36,000
36" Flap Gate	EA	1	15,000	15,000
36" Sluice Gate	EA	1	30,000	30,000
River Outfall Structure, concrete	CY	3	840	2,520
River Outfall Structure, electrical	LS	1	12,000	12,000
Miscellaneous	LS	1	12,000	12,000
Grand Total				4,300,000