



CITY OF MANTECA - FIRE DEPARTMENT

FIRE PREVENTION BUREAU

1154 S. UNION ROAD • MANTECA, CA 95337

(209) 456-8340 • FAX (209) 923-8936

AMUSEMENT PERMIT REQUIREMENTS

105.6.2 Amusement Building. An operational permit is required to operate a special amusement building.

Special Amusement Building- A building that is temporary, permanent or mobile that contains a device or system that conveys passengers or provides a walkway long, around or over a course in any direction as a form of amusement arranged so that the egress path is not readily apparent.

1017.2 Limitations. Exit access travel distance shall not exceed the values given CFC Table 1017.2

907.2.12 Fire Alarm. An automatic smoke detection system shall be provided in special amusement building in accordance with sections 907.2.12.1 through 907.2.12.3

914.7.1 Automatic sprinkler system. Special amusement buildings shall be equipped though out with an automatic sprinkler system. Where the special amusement building is temporary, the sprinkler water supply shall be of an approved temporary means

Exceptions: Automatic sprinklers are not required where the total floor area of a temporary special amusement building is less than 1,000 sq. ft. and the travel distance from any point to an exit is less than 50 ft.

308.1 Open Flames, fire and burning on all premises shall be in accordance with Sections 308.11 through 308.4.1 and with other applicable sections of this code.

Additional requirements may apply.