



## **CITY OF MANTECA - FIRE DEPARTMENT**

### **FIRE PREVENTION BUREAU**

1154 S. UNION ROAD • MANTECA, CA 95337

(209) 456-8340 • FAX (209) 923-8936

## **MISCELLANEOUS COMBUSTIBLE STORAGE OPERATIONAL PERMIT REQUIREMENTS**

---

**105.6.30** An operational permit is required to store in any building or upon any premises in excess of 2,500 cubic feet (71m<sup>3</sup>) gross volume of combustible empty packing cases, boxes, barrels or similar containers, rubber tires, rubber, cork or similar combustible material.

**315.3 Storage in buildings.** Storage of materials in building shall be orderly and stacks shall be stable. Storage of combustible materials shall be separated from heaters or heating devices by distance or shielding so that ignition cannot occur.

**315.3.1 Ceiling clearance.** Storage shall be maintained 2 feet or more below the ceiling in nonsprinklered areas of buildings or not less than 18 inches below sprinkler head deflectors in sprinklered areas of buildings.

**315.3.2 Means of egress.** Combustible material shall not be stored in exits or enclosures for stairways and ramps.

**315.3.3 Equipment rooms.** Combustible material shall not be stored in boiler rooms, mechanical rooms, and electrical equipment rooms or in fire command centers as specified in Section 508.1.5.

**315.4.2 Height.** Storage in the open shall not exceed 20 feet in height.

Additional requirements may apply.